



# RELIABILITY STANDARD IMPLEMENTATION GUIDELINES

Published: December 2015





# IMPORTANT NOTICE

## Purpose

This document has been prepared by AEMO as required by clause 11.78.4 (a) of the National Electricity Rules (Rules), and has effect only for the purposes set out in the Rules.

## Disclaimer

This document or the information in it may be subsequently updated or amended. This document might also contain information which is provided for explanatory purposes. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the Rules, or any other applicable laws, procedures or policies. AEMO has made every effort to ensure the quality of the information but cannot guarantee its accuracy or completeness or its suitability for particular purposes.

To the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this report:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.



# CONTENTS

<b>1. INTRODUCTION</b>	<b>4</b>
1.1 Purpose and scope	4
1.2 Related documents	4
1.3 The Reliability Standard	5
1.4 AEMO's process for managing low reserve or lack of reserve conditions	6
<b>2. RELIABILITY STANDARD IMPLEMENTATION PROCESSES</b>	<b>7</b>
2.1 Electricity Statement of Opportunities	7
2.2 Energy Adequacy Assessment Projection	9
2.3 Projected Assessment of System Adequacy	10
2.4 Summary of assumptions	15
<b>GLOSSARY</b>	<b>16</b>

# TABLES

Table 1 Related Documents	4
Table 2 Summary of processes that AEMO uses to implement the reliability standard	7
Table 3 Summary of assumptions	15
Table 4 Glossary	16



# 1. INTRODUCTION

## 1.1 Purpose and scope

These are the *reliability standard implementation guidelines* (RSIG or Guidelines) made under clause 3.9.3D of the National Electricity Rules (NER). They outline current processes that evaluate the market against the *reliability standard*.

These Guidelines have effect only for the purposes set out in clause 3.9.3D of the NER. The NER and the *National Electricity Law* prevail over these Guidelines to the extent of any inconsistency.

The Guidelines set out how the *Australian Energy Market Operator* (AEMO) implements the *reliability standard* and the approach and assumptions AEMO uses to implement the *reliability standard* in relation to:

- Demand for electricity.
- Reliability of existing and future generation.
- Intermittent generation.
- Energy constraints.
- The treatment of extreme weather events.
- Network constraints.

## 1.2 Related documents

**Table 1 Related Documents**

Reference	Title	Location
Demand Forecasting	Load Forecasting SO_OP3710	<a href="http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Load-Forecasting-SO_OP3710">http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Load-Forecasting-SO_OP3710</a>
Directions	Intervention, Direction and Clause 4.8.9 Instructions SO_OP3707	<a href="http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Intervention-Direction-and-Clause-Instructions-SO_OP3707">http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Intervention-Direction-and-Clause-Instructions-SO_OP3707</a>
EAAP	Energy Adequacy Assessment Projection	<a href="http://www.aemo.com.au/AEMO%20Home/Electricity/Resources/Reports%20and%20Documents/EAAP">http://www.aemo.com.au/AEMO%20Home/Electricity/Resources/Reports%20and%20Documents/EAAP</a>
ESOO	Electricity Statement of Opportunities (ESOO) web page	<a href="http://www.aemo.com.au/Electricity/Planning/Electricity-Statement-of-Opportunities">http://www.aemo.com.au/Electricity/Planning/Electricity-Statement-of-Opportunities</a>
MTPASA	MTPASA Process Description	<a href="http://www.aemo.com.au/Electricity/Market-Operations/Dispatch/MTPASA-Process-Description-and-Reserve-Forecasts">http://www.aemo.com.au/Electricity/Market-Operations/Dispatch/MTPASA-Process-Description-and-Reserve-Forecasts</a>
MRL	ROAM Consulting Final Report for Operational MRLs – 2010 MRL Recalculation	<a href="http://www.aemo.com.au/Electricity/Market-Operations/Reserve-Management/Regional-Minimum-Reserve-Levels">http://www.aemo.com.au/Electricity/Market-Operations/Reserve-Management/Regional-Minimum-Reserve-Levels</a>
MTPASA capacity reserves	Assessing Reserve Adequacy in the NEM	<a href="http://www.aemo.com.au/Electricity/Planning/Related-Information/Assessing-Reserve-Adequacy">http://www.aemo.com.au/Electricity/Planning/Related-Information/Assessing-Reserve-Adequacy</a>
Network constraints	Constraint Implementation Guidelines	<a href="http://www.aemo.com.au/Electricity/Market-Operations/Congestion-Information-Resource/Constraint-Implementation-Guidelines">http://www.aemo.com.au/Electricity/Market-Operations/Congestion-Information-Resource/Constraint-Implementation-Guidelines</a>
Network constraints	Constraint Formulation Guidelines	<a href="http://www.aemo.com.au/Electricity/Market-Operations/Congestion-Information-Resource/Constraint-Formulation-Guidelines">http://www.aemo.com.au/Electricity/Market-Operations/Congestion-Information-Resource/Constraint-Formulation-Guidelines</a>
Reserve contracts – dispatch and activation	Procedure for the Dispatch and Activation of Reserve Contracts SO_OP3717	<a href="http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Procedure-for-the-Dispatch-and-Activation-of-Reserve-Contracts-SO_OP3717">http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Procedure-for-the-Dispatch-and-Activation-of-Reserve-Contracts-SO_OP3717</a>



Reference	Title	Location
Reserve contracts – Procuring reserve contracts	Procedure for the Exercise of Reliability and Emergency Reserve Trader (RERT) at the AEMO web page	<a href="http://www.aemo.com.au/Electricity/Market-Operations/Reserve-Management/Procedure-for-the-Exercise-of-Reliability-and-Emergency-Reserve-Trader-RERT">http://www.aemo.com.au/Electricity/Market-Operations/Reserve-Management/Procedure-for-the-Exercise-of-Reliability-and-Emergency-Reserve-Trader-RERT</a>
Short term weather events	Power system security guidelines SO_OP3715	<a href="http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Power-System-Security-Guidelines-SO_OP3715">http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Power-System-Security-Guidelines-SO_OP3715</a>
STPASA	Short Term Reserve Assessment SO_OP3703	<a href="http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Short-Term-Reserve-Management-SO_OP3703">http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Short-Term-Reserve-Management-SO_OP3703</a>
STPASA	STPASA Process Description	<a href="http://www.aemo.com.au/Electricity/Market-Operations/Dispatch/STPASA-Process-Description">http://www.aemo.com.au/Electricity/Market-Operations/Dispatch/STPASA-Process-Description</a>

## 1.3 The Reliability Standard

The *reliability standard* is a measure of the effectiveness, or sufficiency, of installed capacity to meet demand. It is defined in clause 3.9.3C of the NER as the maximum expected *unserved energy* (USE), as a percentage of total energy, in a region over a financial year, and is currently set at 0.002%. USE is measured in GWh.

The USE that contributes to the *reliability standard* is defined in clause 3.9.3C (b) of the NER and excludes power system security events, network outages not associated with inter-regional flows and industrial action or acts of God.

The NER does not give specific direction to AEMO on how to implement the *reliability standard*, but it does require AEMO to perform the following functions in accordance with the RSIG:

### 1. Clause 3.7.2 MTPASA

(f)(6) Identify and quantify any projected failure to meet the *reliability standard* as assessed in accordance with the RSIG.

### 2. Clause 3.7.3 STPASA

(h)(5) Identify and quantify any projected failure to meet the *reliability standard* as assessed in accordance with the RSIG.

### 3. Clause 4.2.7 *Reliable operating state*

(c) Assess whether the *power system* meets, and is projected to meet, the *reliability standard*, having regard to the RSIG.

### 4. Clause 4.3.1 Responsibility of AEMO for power system security

(l) Monitor demand and *generation* capacity in accordance with the RSIG and, if necessary, initiate action in relation to a *relevant AEMO intervention event*.

(m) Publish as appropriate, information about the potential for, or the occurrence of, a situation which could significantly impact, or is significantly impacting, on *power system security*, and advise of any *low reserve* condition for the relevant periods determined in accordance with the RSIG.

### 5. Clause 4.8.4 Declaration of conditions

(a) AEMO may declare a *low reserve* condition when it considers that the balance of *generation* capacity and demand for the period being assessed does not meet the *reliability standard* as assessed in accordance with the RSIG.

(b) AEMO may declare a *lack of reserve level 1, 2 or 3* to advise whenever *capacity reserves* reduce below the level required to manage *credible contingency events*.



## 1.4 AEMO's process for managing low reserve or lack of reserve conditions

If AEMO declares a *lack of reserve (LOR)* or *low reserve condition (LRC)*, AEMO will follow the processes set out in clauses 4.8.5A and 4.8.5B. This includes publishing of any foreseeable circumstances that may require AEMO to implement an *AEMO intervention event*.

The objective of implementing an AEMO *intervention event* is to maintain the reliability of supply and power system security where practicable, over the period *low reserve* or *lack of reserve* condition exists. *AEMO intervention events* include:

- (a) Issuing an instruction or direction in accordance with clause 4.8.9; or
- (b) Exercising the reliability and emergency reserve trader in accordance with rule 3.20

Details on these can be found in the Intervention, Direction and Clause 4.8.9 Instructions document and the Procedure for the Dispatch and Activation of Reserve Contracts SO\_OP3717 document described in section 1.2.



## 2. RELIABILITY STANDARD IMPLEMENTATION PROCESSES

AEMO implements the *reliability standard* using forecasts and projections over different timeframes. AEMO uses the following processes:

1. Electricity *statement of opportunities* (ESOO) to provide market information over a ten year projection to assist planning by existing and potential generators and market participants.
2. *Energy adequacy assessment projection* (EAAP) to forecast USE for energy constrained scenarios over a two year projection.
3. MTPASA to forecast peak *capacity reserve* conditions over a two year projection.
4. STPASA to forecast *capacity reserve* over a six day projection.

Detailed information about each of these processes and the methodologies applied in them can be found on AEMO's website as listed in section 1.2. This section of the Guidelines describes how each of the processes evaluates key components that contribute to AEMO's forecast of reliability. Different assumptions used under the various processes reflect the study time frame and hence level of uncertainty in the inputs.

Table 3 explains the processes AEMO undertakes to forecast *reliability*, inform *Market Participants* and *Network Service Providers* if the reliability standard is likely to be breached, and intervene where necessary.

**Table 2 Summary of processes that AEMO uses to implement the reliability standard**

Process	Study Time Frame/Publication Frequency	Assessment Method	Primary Action	Second Action	Assumption for Potential Breach of Reliability Standard
ESOO	10 year/Annually	USE	Inform		Forecast USE>0.002% in any forecast year
EAAP	2 year/Quarterly	USE	Inform	4.8.9 instruction, RERT of direction	Forecast USE>0.002% in any forecast year
MTPASA	2 year/Weekly	Capacity	Inform	4.8.9 instruction, RERT of direction	Reserves fall short of the Minimum Reserve Level (MRL)
STPASA	6 day/2 hours	Capacity	Inform	4.8.9 instruction, RERT of direction	LOR2 or LOR3

### 2.1 Electricity Statement of Opportunities

AEMO is required to publish an Electricity Statement of Opportunities (ESOO) annually under clause 3.13.3(q) of the NER. The ESOO provides information which can help stakeholders plan their operations over a ten-year outlook period, including information about the future supply demand balance.

The ESOO also indicates when *generation* or demand management capacity or augmentation of the *power system* is required to meet the *reliability standard*, using probabilistic modelling to determine the regional USE at an hourly resolution. This involves using time-sequential, security-constrained optimal dispatch simulations, incorporating Monte-Carlo simulations. AEMO compares the probability-weighted USE assessment against the *reliability standard*, and identifies potential future breaches. Detail on this approach and assumption can be found in the methodology document.<sup>1</sup>

<sup>1</sup> See AEMO ESOO web page: <http://www.aemo.com.au/Electricity/Planning/Electricity-Statement-of-Opportunities>



AEMO then publishes details of any forecast LRC where the *reliability standard* may be breached. AEMO generally does not take any further action to ensure a response to any potential breaches of the *reliability standard* identified in the ESOO.<sup>2</sup>

The following sub-sections outline some key inputs to the ESOO model. A detailed description of the ESOO modelling methodology is available on the ESOO webpage as listed in section 1.2.

### 2.1.1 ESOO generation capacity

For the generation component of the ESOO assessment, AEMO uses the total of current generation capacity plus any committed future generation<sup>3</sup> and withdrawals, obtained from operators of generating plant in the NEM<sup>4</sup>. AEMO does not assume or forecast any further new generation capacity. Generic annual planned outages are scheduled and optimised in lower demand periods and forced outages are stochastically modelled using probabilities derived from historical performance or expert advice where historical information is not available.

### 2.1.2 ESOO intermittent generation

For *intermittent* generation, AEMO prepares ten year *intermittent* generation profiles based on historical performance where available or meteorological data for new or committed generation. These generation profiles are a deterministic input to the Monte-Carlo simulations. Detail on this approach and assumptions can be found in the ESOO methodology document.

As a matter of priority, AEMO is seeking a way to adopt a more probabilistic approach for modelling intermittent generation. ~~AEMO is investigating this deterministic profile and seeking a way to adopt a more probabilistic approach.~~ Any future change in methodology will be communicated to stakeholders before it is applied, and highlighted in the ESOO methodology document.

### 2.1.3 ESOO energy constraints

The ESOO process accounts for projected *energy constraints* via inputs to the ESOO model. Any *energy constraint*, such as low water levels of dams used by hydroelectric *Generators*, is an input to the model as total *energy* available for the particular *Generator*. These assumptions are based on historical observations, and long-term average hydroelectric yields assessed by AEMO in consultation with relevant stakeholders. The same principle applies for any other *energy limitation* affecting a *Generator* in the model.

### 2.1.4 ESOO forecast demand

For the forecast demand component of the ESOO, AEMO uses the most recent National Electricity Forecasting Report (NEFR)<sup>5</sup>. The NEFR projects *energy* and *maximum demand* forecasts for the National Electricity Market (NEM). AEMO converts the *maximum demand* forecasts into hourly, or half-hourly, demand profiles based on historical demand patterns. The demand profile also incorporates NEFR assumptions on future rooftop PV and battery storage penetration.

Extreme weather events are considered through the use of demand profiles derived from the 10% *probability of exceedance*<sup>6</sup> (10% POE) *maximum demand* forecasts. A combination of both 50% POE and 10% POE demand profiles are used probabilistically in the Monte-Carlo simulations to develop the expected USE.

<sup>2</sup> Unless the breach is identified in the NTNDP as an *NSCAS gap* and will not be met by the relevant *Transmission Network Service Provider*.

<sup>3</sup> Committed future generators represent generation that is considered to be proceeding based on AEMO's commitment criteria, for more detail see AEMO Generation Information page: <http://aemo.com.au/Electricity/Planning/Related-Information/Generation-Information>

<sup>4</sup> See ESOO Methodology:

<http://www.aemo.com.au/Electricity/Planning/~/media/Files/Electricity/Planning/Reports/ESOO/2015/2015%20ESOO%20Methodology%20document.ashx>

<sup>5</sup> See AEMO NEFR web page: <http://www.aemo.com.au/Electricity/Planning/Forecasting/National-Electricity-Forecasting-Report>

<sup>6</sup> Probability of exceedance is a chance that the observed value is greater than the reported. A 10% probability of exceedance means that there is a 10% chance that the outcome is greater than the reported value.



### 2.1.5 Network constraints

AEMO continues to update and refine *network constraints* through its modelling projects throughout the year. The ESOO implements the latest version of pre-dispatch constraints, as well as the *network constraints* associated with future planned *network upgrades*. Pre-dispatch constraints consider feedback terms in the right hand side of the equations, using the previous periods' dispatch to help formulate the current periods' limits. Given the ten-year outlook period, ESOO constraint equations need to make assumptions on the future inertia of the system, and whether reactive plants are in service. Such assumptions are made using long term averages or estimates based on demand levels.

Detailed information on *network constraints* can be found in the network constraints documents listed in section 1.2.

## 2.2 Energy Adequacy Assessment Projection

The Energy Adequacy Assessment Projection (EAAP) implements the *reliability standard* over a two-year timeframe. In addition to the demand outlook, generation capacity availability and network constraints, EAAP particularly focus on the impact of potential *energy constraints*, such as water shortages during drought conditions, and identifies and reports forecast USE that exceeds the *reliability standard*.

AEMO is required to publish an EAAP in accordance with NER clause 3.7C. The EAAP makes available to the market an analysis that quantifies the impact of potential *energy constraints* on *energy availability* for a range of scenarios, specified in the *EAAP guidelines*. AEMO identifies potential periods of USE and quantifies projected annual USE that may breach the *reliability standard*.

The *energy constraints* that AEMO considers for the EAAP are defined in the *EAAP guidelines*. AEMO uses a market model to forecast two years at hourly resolution for these *energy constraint* scenarios. This involves using time-sequential Monte-Carlo market dispatch simulations. It uses a probability-weighted USE assessment to identify any potential *reliability standard* breaches.

The following sub-sections outline some key inputs to the EAAP model. A detailed description of EAAP modelling is available on AEMO's website as listed in section 1.2.

### 2.2.1 EAAP Generation capacity

Generation capacity is an input to the EAAP model. AEMO uses the most recent MTPASA offers to derive total capacity and planned outage information.

### 2.2.2 EAAP intermittent generation

*Intermittent generation* forecasts are the same generation profiles used in ESOO, which are based on historical performance where available or meteorological data for new or committed generation.

The semi-scheduled *intermittent generation* forecasts are aggregated per region and then added to the scheduled generation capacity of the associated region. Semi-scheduled *intermittent generation* is added to scheduled *generation* to make up the total *generation* dispatched by the *central dispatch* mechanism.

The non-scheduled *intermittent generation* forecasts are aggregated per region and then subtracted from the associated regional demand forecast. Non-scheduled *intermittent generation* is subtracted from demand because it is not dispatched by the *central dispatch* mechanism and thereby appears as negative demand.



### 2.2.3 EAAP energy constraints

AEMO's approach is to model EAAP scenarios that reflect credible *energy constraints*, as identified in the *EAAP guidelines*. The energy constraint information is provided to AEMO by participants through the *Generator Energy Limitation Framework* (GELF)<sup>7</sup>.

### 2.2.4 EAAP demand

AEMO converts the most recent NEFR *energy* and *maximum demand* forecasts into an hourly demand profile based on historical demand patterns. The simulations assess both 50% and 10% POE *maximum demand* profiles. Extreme weather events are considered using of demand profiles derived from the 10% POE *maximum demand* forecasts.

### 2.2.5 Network constraints

The EAAP simulations model the network power transfer capability using system normal constraint equations only. Detailed information on the preparation of EAAP *network constraints* can be found in the *EAAP guidelines*. The EAAP currently uses the same constraint equations that are used for STPASA, see section 2.3.2.6. AEMO is investigating whether it is feasible to use the more detailed ESOO constraint set for EAAP modelling in future. Any change in methodology will be communicated to stakeholders before it is applied, and highlighted in the *EAAP guidelines*.

## 2.3 Projected Assessment of System Adequacy

~~AEMO's projected assessment of system adequacy processes (PASA) collect, analyse and publish information that will inform the market regarding forecasts of supply and demand. AEMO's projected assessment of system adequacy processes (PASA) collect, analyse and disclose projected information about power system security and reliability of supply. These processes inform Registered Participants to enable them to make decisions about supply, demand and outages of transmission networks.~~

PASA is administered in two timeframes:

1. *Medium-term PASA* (MTPASA) – a 24 month projection at daily resolution.
2. *Short-term PASA* (STPASA) – a six day projection at 30 minute resolution.

For the PASA processes, AEMO determines *capacity reserve* levels to assess the reliability of future *generation*. Separate reserve assessments are applied for the MTPASA and STPASA processes. MTPASA identifies LRC and STPASA identifies LOR<sup>8</sup> conditions.

AEMO's response to a capacity shortfall<sup>9</sup>, an LRC or LOR, depends on the extent of the projected shortfall, and the timeframe in which it is projected to arise. AEMO's potential responses include:

- Notifications to the market via reports, data, or market notices.
- Intervening in the market via *directions*<sup>10</sup> under NER clause 4.8.9.
- Intervening in the market by *dispatching*<sup>11</sup> contracted reserve<sup>12</sup>.

AEMO assumes that if a period of LRC or LOR is identified, then there is a risk that the *reliability standard* may be breached.

<sup>7</sup> See Rules 3.7C (b) (g) to (j)

<sup>8</sup> See AEMO procedure (section 6) Short Term Management SO\_OP3703 on web page [http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Short-Term-Reserve-Management-SO\\_OP3703](http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Short-Term-Reserve-Management-SO_OP3703)

<sup>9</sup> See Assessing Reserve Adequacy in the NEM web page <http://www.aemo.com.au/Electricity/Planning/Related-Information/Assessing-Reserve-Adequacy>

<sup>10</sup> See Intervention, Direction and Clause 4.8.9 Instructions SO\_OP3707 web page: [http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Intervention-Direction-and-Clause-Instructions-SO\\_OP3707](http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Intervention-Direction-and-Clause-Instructions-SO_OP3707)

<sup>11</sup> Procedure for the Dispatch and Activation of Reserve Contracts SO\_OP3717 web page: [http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Procedure-for-the-Dispatch-and-Activation-of-Reserve-Contracts-SO\\_OP3717](http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Procedure-for-the-Dispatch-and-Activation-of-Reserve-Contracts-SO_OP3717)

<sup>12</sup> See RERT web page: <http://www.aemo.com.au/Electricity/Market-Operations/Reserve-Management/Procedure-for-the-Exercise-of-Reliability-and-Emergency-Reserve-Trader-RERT>



### 2.3.1 Medium Term PASA (MTPASA)

AEMO implements the *reliability standard* over a two-year timeframe by providing a *capacity reserve assessment* as part of the MTPASA process, which is run at least weekly. This component of the broader MTPASA process identifies potential capacity shortfalls known as LRC. The *reliability standard* is implemented by identifying, disclosing and responding to periods of forecast LRC.

AEMO declares a LRC if *capacity reserves* are projected to be inadequate on any given day. Capacity reserves are the difference between the PASA availability *participants* have offered and expected demand estimated by AEMO according to the PASA processes. To assess supply adequacy, these *capacity reserves* are compared against Minimum Reserve Levels (MRLs). This provides a fast and timely assessment of supply adequacy without needing to compute USE explicitly using a large number of Monte Carlo simulations.

MRLs represent the minimum level of *capacity reserves* that must be carried in each *region* to avoid exceeding 0.002% USE in a given financial year. They are calculated by AEMO through market modelling, taking into account *inter-regional* reserve sharing capability, network system normal constraints, and generation forced outage probabilities. Due to the time consuming nature of the MRL analysis, MRLs are only updated at AEMO's discretion. The methodology for calculating MRLs is available on AEMO's website.

Applying MRL in the MTPASA assists to identify potential reserve shortfalls in the NEM. However, AEMO may apply probabilistic studies such as EAAP to confirm the LRC findings of MTPASA before intervening in response to projected shortfalls.

AEMO responses to projected LRC in MTPASA may be to take direct action in the form of directions - for example, directing a *Generator* to reschedule an outage - or using the *reliability and emergency reserve trader* (RERT). The RERT can only be used if the expected reserve shortfall is within the next nine months. AEMO's RERT role is scheduled to expire on 30 June 2016.

A detailed description of the MTPASA process is available on AEMO's website as listed in section 1.2.

#### 2.3.1.1 MTPASA generation capacity reserve assessment

AEMO assesses *reserve capacity*<sup>9</sup> by comparing a two year daily peak capacity profile to the MTPASA daily peak demand profile. If a pre-determined *reserve requirement*, MRL, is breached then AEMO may take action to attempt to restore the required *reserve capacity*.

The daily peak capacity profile used in the MTPASA process is derived from several sources:

- Scheduled *Generators* are required to submit to AEMO a daily PASA availability<sup>13,14</sup>. The availabilities submitted represent the generation capacity that could be made available within 24 hours taking into account the ambient weather conditions at the time of 10% POE demand.
- Intermittent *Generators* submit capacity information, which is then used in AEMO's process of forecasting available *intermittent* generation capacity (see section 2.1.2).
- Committed development generation projects are included in the capacity forecast by using expected commissioning timeframes and associated availabilities.

Forced outages are assessed probabilistically as part of the MRL. The probability of forced outages is based on historical performance and consistent with ESOO and EAAP assumptions used at the time the MRLs were updated.

<sup>13</sup> For MTPASA see NER Clause 3.7.2(d) and for STPASA see NER Clause 3.7.3(e)(2).

<sup>14</sup> PASA availability is a defined term in the NER: The physical plant capability (taking ambient weather conditions into account in the manner described in the procedure prepared under clause 3.7.2(g)) of a scheduled generating unit, scheduled load or scheduled network service available in a particular period, including any physical plant capability that can be made available during that period, on 24 hours' notice.



### 2.3.1.2 MTPASA intermittent generation

AEMO uses two models: one to forecast *intermittent wind generation*, Australian Wind Energy Forecasting System (AWEFS<sup>15</sup>) and the other to forecast *intermittent solar generation* Australian Solar Energy Forecasting System (ASFES<sup>16</sup>).

The semi-scheduled *intermittent generation* forecasts are based on 90% POE per facility and the non-scheduled *intermittent generation* forecasts are based on 90% POE and aggregated per region.

The *intermittent generation* forecasts are aggregated by *region* and then added to the *scheduled generation* capacity (*PASA availability* submitted by *Market Participants*) in the associated region.

### 2.3.1.3 MTPASA energy constraints

As part of the MTPASA process *energy constrained Generators* submit weekly *energy limits*. The MTPASA process then allocates *energy constrained generation* according to the ratio of forecast demand to aggregated MTPASA *generation availability*.

AEMO's approach in the MTPASA timeframe is to allocate *energy constrained generation* to periods where forecast demand is high with respect to available capacity. This maximises *capacity reserves* throughout the MTPASA period. AEMO assumes that this reflects a likely market outcome that appropriately minimises forecast capacity shortfalls.

### 2.3.1.4 MTPASA demand

The MTPASA daily peak demand profile is a 24 month 10% POE forecast of daily *maximum demand* for each *region*. This forecast is based on the *maximum demand* forecast in the latest NEFR regional demand forecast. AEMO uses the seasonal peak demand forecasts from the NEFR, then calculates daily peak demands based on historical relationships between season peak demand and:

- Seasonal weather variations such as seasonal temperature.
- Day type profiles such as weekday, weekend, school holidays, public holidays and daylight saving.
- Large industrial load (LIL) demand and consumption expectations.

The MTPASA solves using daily peak demands in all regions. The probability of peak demand diversity between joint regions is taken into account when developing the MRLs, i.e. MRLs are reduced by the expected ability to import surplus reserves from other regions.

### 2.3.1.5 Network constraints

*Capacity reserve* is assessed in accordance with the MTPASA process, which includes assumptions on reserve sharing based on interconnector capacities and constraints. The MRLs are initially calculated based on system normal pre-dispatch constraints, the same constraints that are used for ESOO.

Then MRLs are adjusted to the *interconnector limiting constraints* that apply in MTPASA (regional net import/export limit constraints) to more accurately reflect the reserve sharing capability of the *interconnector*. Detail on preparation of PASA network constraints can be found in the MTPASA process description available on AEMO's website.

## 2.3.2 Short Term PASA (STPASA)

AEMO implements the *reliability standard* over a six day timeframe by providing a *capacity reserve* assessment as part of the STPASA process. *Capacity reserves* are measured against *credible contingency events* to indicate if supply is sufficient to meet demand and thereby avoid USE. If necessary, AEMO declares a LOR in accordance with clause 4.8.4 of the NER. There are three levels

<sup>15</sup> See AEMO AWEFS web page: <http://www.aemo.com.au/Electricity/Market-Operations/Dispatch/AWEFS>.

<sup>16</sup> ASEFS is the same AWEFS except solar irradiation is used as an input rather than wind speed.



of LOR which can all be found in this clause. In the STPASA timeframe, it is not realistic to consider USE over a financial year in a six-day STPASA timeframe. As ST PASA has access to short term weather and participant offer information it there is less input uncertainty than is the case for longer term forecasts such as MT PASA and ESOO. Given the proximity to operational timeframes, intervention decisions aim to minimise expected USE, with intervention being considered to address a forecast LOR2 or LOR3.

A detailed description of the STPASA process is available on AEMO's website.

#### **2.3.2.1 STPASA generation capacity reserve assessment**

For the STPASA six day timeframe AEMO assesses *capacity reserve*<sup>17</sup> using a deterministic reserve assessment. If the *reserve level* for any *region* is less than the LOR1 level for that region, AEMO advises the existence of LOR1 condition for that region to the market. If the *reserve level* indicates a LOR2 or LOR3 then AEMO may take action to restore the required *reserve capacity* by implementing an *AEMO intervention event*.

#### **2.3.2.2 STPASA intermittent generation**

AEMO uses the AWEFS and ASFES models to forecast STPASA *intermittent generation*. The model outputs for STPASA are a half hourly generation contribution, based on 50% POE per facility.

The semi-scheduled *intermittent generation* forecasts are aggregated per region and then added to the scheduled *generation capacity* (participant PASA offers) of the associated region. Non-scheduled *intermittent generation* is subtracted from the associated regional demand forecast.

#### **2.3.2.3 STPASA scheduled generation capacity**

The STPASA draws information on scheduled *generation* from the *availability* data submitted with generators' market offers. When a *slow-start generating unit* plans to be off-line at a specific time but could operate had it received a direction 24 hours previously, the *PASA availability* of that unit will indicate what capacity AEMO can assume at that specific time.

#### **2.3.2.4 STPASA Demand**

For the demand component AEMO uses a 50% POE, 30 minute resolution, demand forecast<sup>18</sup> for each NEM region. This forecast is produced by AEMO's automated Demand Forecasting System<sup>19</sup> (DFS).

The main inputs to the DFS are:

- Half-hourly historical demand for NEM *regions*.
- Historical and forecast weather data.
- Non-scheduled wind generation forecasts from AWEFS.
- Non-scheduled solar generation forecasts from ASEFS.

Calendar information such as weekday/weekend, school holidays, public holidays and daylight savings information.

<sup>17</sup> See section 2.1.2 of AEMO Short Term PASA Process Description on the AEMO STPASA web page: <http://www.aemo.com.au/Electricity/Market-Operations/Dispatch/STPASA-Process-Description>

<sup>18</sup> For further information about the STPASA demand forecast see AEMO Load Forecasting procedure (SO\_OP3710) web page: [http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Load-Forecasting-SO\\_OP3710](http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Load-Forecasting-SO_OP3710)

<sup>19</sup> See Load Forecasting SO\_OP3710 web page: [http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Load-Forecasting-SO\\_OP3710](http://www.aemo.com.au/Electricity/Policies-and-Procedures/System-Operating-Procedures/Load-Forecasting-SO_OP3710)



### 2.3.2.5 Energy constraints

As part of the STPASA process, *energy constrained generators* submit daily *energy availability forecasts*. The STPASA process then allocates this *energy limited generation*, over the forecast period, maximising *capacity reserves* throughout the PASA period.

AEMO's approach in the STPASA timeframe is thereby to allocate *constrained generation* efficiently, usually to periods of high demand. AEMO assumes that this best reflects a likely market outcome that appropriately minimises forecast *capacity shortfalls*.

*Capacity reserve* is then assessed in accordance with the STPASA process.

### 2.3.2.6 Network constraints

*Capacity reserve* is assessed in accordance with the STPASA process. Even in the short STPASA timeframe, assumptions similar to those made in the ESOO process need to be made in formulating STPASA network constraint equations, to address uncertainty around future power system conditions. The difference between STPASA and ESOO constraints is that STPASA assesses half-hourly snapshots of *capacity reserves* without taking into account the previous period's dispatch. This means that STPASA cannot use certain types of data that is available to the dispatch and pre-dispatch systems, such as supervisory control and data acquisition (SCADA) terms. These terms provide previous period feedback in network constraints to reflect the real-time data collections. More detail on the preparation of PASA network constraints can be found in the STPASA process description in section 1.2.

### 2.3.2.7 Extreme temperature events

Extreme ambient temperatures affect both generation availability and forecast demand in the STPASA timeframe.

For *generation availability*, the capacity offered by *Generators* is based on a predetermined temperature. In the event of an extreme weather event *Generators* are required to revise their availability offers, with respect to a revised forecast temperature covering the extreme weather event. The revised *generation availability* offers are then assessed in accordance with the STPASA process.

When the forecast temperatures exceed the regional reference temperatures AEMO publishes a market notice reminding *Generators* to review the *available capacities* in their *dispatch offers* consistent with the forecast extreme temperature conditions. Further details are available in the Short Term Reserve Assessment operating procedure in section 1.2.

For demand, the AEMO DFS is periodically updated with forecast weather over the six day forecast. Therefore extreme temperature events are automatically incorporated into the DFS as the event moves into the six day forecast timeframe.



## 2.4 Summary of assumptions

Table 3 Summary of assumptions

	ESOO	EAAP	MTPASA	STPASA
How is reliability standard implemented?	Directly assess USE expectations based on probabilistic modelling.	Directly assess USE expectations based on probabilistic modelling.	Calculate minimum reserve levels to approximate the point at which USE would exceed 0.002%. Assess whether capacity less MRL exceeds demand across assessment period.	Is any region in LOR 2 or LOR3?
Demand	10% POE and 50% POE hourly profiles based on NEFR.	10% POE and 50% POE hourly profiles based on NEFR.	10% POE daily peak load based on NEFR and past trends, day type and special events.	50% POE half hour demand based on expected weather trends.
Intermittent generation	Hourly profiles based on historical data.	Hourly, 90% POE based on AWEFS and ASEFS.	Daily, 90% POE based on AWEFS and ASEFS.	Half-hourly, 50% POE based on AWEFS and ASEFS.
Scheduled generation capacity and outages	Annual survey	MTPASA offers.	MTPASA offers.	Available capacity – PASA availability.
Energy constraints	Monthly inflow of water assumed for hydro plants based on historical observations.	Provided through <i>GELF</i> .	Weekly energy constraints submitted by participants.	Daily energy constraints are considered.
Extreme weather events	Use of both 10%- and 50% POE.	Scenarios defined in the EAAP guidelines.	Use 10% POE demand and 90% POE contribution from intermittent generation. Scheduled generation is also considered available at 10% POE ambient conditions.	50% POE.
Network constraints	System normal pre-dispatch constraints.	System normal constraints <b>and-outage constraints from the Network Outage Schedule</b>	MTPASA type constraints and outage information from the Network Outage Schedule.	STPASA type constraints and outage information from the Network Outage Schedule.



## GLOSSARY

- a) In this document, a word or phrase *in this style* has the same meaning as given to that term in the National Electricity Rules.
- b) In this document, capitalised words or phrases or acronyms have the meaning set out opposite those words, phrases, or acronyms in the table below.
- c) Unless the context otherwise requires, this document will be interpreted in accordance with Schedule 2 of the *National Electricity Law*.

**Table 4 Glossary**

Term	Definition
AEMO	Australian Energy Market Operator
ASEFS	Australian Solar Energy Forecasting System
AWEFS	Australian Wind Energy Forecasting System
DFS	Demand Forecasting System
EAAP	<i>Energy adequacy assessment projection</i>
ESOO	<i>Electricity statement of opportunities</i>
GELF	<i>Generator Energy Limitation Framework</i>
GWh	Gigawatt hours (energy)
LOR	<i>Lack of reserve</i>
LRC	<i>Low reserve condition</i>
MTPASA	<i>Medium term PASA</i>
MW	Megawatt
NEFR	National Electricity Forecasting Report
NEM	National Electricity Market
NER	National Electricity Rules
NTNDP	National Transmission Network Development Plan
NSCAS	Network Support and Control Ancillary Services
PASA	<i>Projected assessment of system adequacy process</i>
POE	Probability of Exceedance
RERT	<i>Reliability and emergency reserve trader</i>
RSIG	<i>Reliability standard implementation guidelines</i>
STPASA	<i>Short term PASA</i>
USE	<i>Unserved energy</i>