Insert Company Logo here

DRAFT DETERMINATION – PARTICIPANT RESPONSE PACK

METER CHURN PACKAGE

Participant: *[Acumen]*

Completion Date: *[7/10/14]*

Table of Contents

1. PROPOSED CHANGES 3

A. PROPOSED CHANGES TO THE METER CHURN PACKAGE 3

1. Proposed Changes

- Meter Churn procedure for Financially Responsible Market Participants (New Document)
- SLP Metering Data Provider Services – Section 8 and Section 9
- SLP Metering Provider Services Category B for Metering Installation Types 1, 2, 3, 4, 5 and 6

NOTE: No proposed changes have been populated please refer to mapping documents and change marked procedures. Please complete where necessary

Please include your comments in the 'Participant Comment' column below.

A. Proposed Changes to the Meter Churn Package

Item	Description	Category	Participant Comments
1	**PROPOSED/ REQUESTED CHANGES**		
1.1	**FRMP – 3.2.1 –**	**Procedure only**	bullet point 2 is missing
1.2	**FRMP - 3.2.1dii**	**Procedure only**	MDPs are supposed to have a full days data in order to com a meter change. Therefore, this should state 'the meter change date plus 1'. However, this also needs to bear in mind commercial terms (contract start dates). I.e. the MDP should be comming a transfer on install date plus 1, or the contract start date, whichever is later. Appreciate the commercial aspect is not a problem for the rules to define.
1.3	**MDP – 8.1.5aiii**	**Procedure only**	Delete "reading" after "the start reading(s)"
1.4		**Procedure only**	As per above, clarity about what date an MDP should COM an interval to interval exchange

Item	Description	Category	Participant Comments
			would be beneficial, ie. Day after install.
1.5	**MP – 4.8.1**	**Procedure only**	Can this clause better clarify what a "request" is? I am assuming that it is a relevant Change Request as per CATS procedures, if so can this clause be modified to reflect this.
1.6	**MP – 4.12.1 a)**	**Procedure only**	Could this clause please be modified to ensure reasonable endeavours are made to contact the metering provider during normal business hours in the location of the MDP?
1.7	**MP – 4.12.1 a)**	**Procedure only**	I would like to see the following added to the end of clause 4.12.1 a) after point ii): If the Meter Provider cannot contact the Metering Data Provider then reasonable endeavours should be used to ensure the meter and associated equipment is returned to the Meter Provider within 2 business days. This will ensure timely return of equipment to the MP so that data can be delivered into the market for settlement purposes.