



Versalux Pty Ltd (ABN 68 005 911 802)
28 Edgerton Road,
(P.O. Box 443)
Mitcham, VIC, 3132
Tel: +61 3 8878 2000 Fax: +61 3 8878 2099

Mr David Ripper
Senior Metrology Engineer
Australian Energy Market Operator Ltd
500 Collins Street
Melbourne, Victoria 3000

11 June, 2014

Dear David,

Re: Submission to include Versalux “Saturn” on the National Electricity Market Load Table

We would like to request for the Versalux Saturn products to be given approval for inclusion on the National Electricity Market Load Tables for Unmetered Loads. These products are being used as part of the City of Mt Barker project.

List of Fixtures

Description

Luminaire	System Wattage
Saturn LED 30P	49.19 W
Saturn LED 30A	49.19 W

Fixture Dimming and Control

These fittings are controlled with a master P.E. cell.

External Marking

The Saturn range do not have large external marking space. However the fixture will contain a label on the inside of the pole access door fixture outlining Lamp type (LED), Wattage, Lamp envelope and Year of manufacture.


Supporting Documents

Our submission is supported with the following documents.

1. Technical data sheet
2. Lamp Circuit Power Test report undertaken by SGS Australia Pty Ltd (NATA accredited)
3. Letter from City of Mt Barker confirming that the fitting will be used as part of the project

We trust this submission meets with your approval. However, should there be any queries or if you require any further information, please don't hesitate to contact me.

Yours sincerely

A handwritten signature in blue ink, appearing to read 'Greg Warner', with a long horizontal flourish extending to the right.

Greg Warner
Director