



Trip of 5A3 and 5A5 lines on 17 February 2020

August 2020

Reviewable Operating Incident Report under the
National Electricity Rules

INCIDENT CLASSIFICATIONS

Classification	Detail
Time and date of Incident	0519 hrs 17 February 2020
Region of incident	New South Wales
Affected regions	New South Wales
Event type	Environmental – lightning
Generation impact	No generation was disconnected as a result of this incident
Customer load impact	No customer load was disconnected as a result of this incident
Associated reports	Nil

ABBREVIATIONS

Abbreviation	Term
AEMC	Australian Energy Market Commission
AEMO	Australian Energy Market Operator
AEST	Australian Eastern Standard Time
kA	Kiloampere
kV	Kilovolt
NEM	National Electricity Market
NER	National Electricity Rules
TNSP	Transmission Network Service Provider

Important notice

PURPOSE

AEMO has prepared this report in accordance with clause 4.8.15(c) of the National Electricity Rules, using information available as at the date of publication, unless otherwise specified.

DISCLAIMER

AEMO has made every reasonable effort to ensure the quality of the information in this report but cannot guarantee its accuracy or completeness. Any views expressed in this report may be based on information given to AEMO by other persons.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this report:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.

COPYRIGHT

© 2020 Australian Energy Market Operator Limited. The material in this publication may be used in accordance with the copyright permissions on AEMO's website.

Contents

1.	Overview	5
2.	The incident	5
2.1	Pre-incident conditions	5
2.2	The incident	5
2.3	TransGrid investigation	6
3.	Power system security	6
3.1	Reclassification	6
4.	Market information	6
5.	Conclusions	7
A1.	System diagram	8

Figures

Figure 1	An overview of the 5A3 and 5A5 lines	8
----------	--------------------------------------	---

1. Overview

This report relates to a reviewable operating incident¹ that occurred on 17 February 2020 in New South Wales. The incident involved the simultaneous trip of Mount Piper – Bayswater 5A3 500 kV line (5A3 line) and Mount Piper – Wollar 5A5 500 kV transmission lines (5A5 line).

There was no loss of generation or customer load as a result of this incident.

As this was a reviewable operating incident, AEMO is required to assess the adequacy of the provision and response of facilities and services and the appropriateness of actions taken to restore or maintain power system security².

AEMO has concluded that:

1. The trip of the 5A3 and the 5A5 lines was due to lightning, and all protections operated as designed and as expected to clear the fault.
2. AEMO correctly reclassified the simultaneous trip of the 5A3 and the 5A5 lines as a credible contingency after the incident.
3. AEMO now considers the 5A3 and the 5A5 lines to be vulnerable transmission lines with a category of Probable³ due to lightning.
4. The power system remained in a secure operating state throughout this incident.

This report is prepared in accordance with clause 4.8.15(c) of the National Electricity Rules (NER). It is based on information provided by TransGrid⁴ and AEMO.

National Electricity Market (NEM) time (Australian Eastern Standard Time [AEST]) is used in this report.

2. The incident

2.1 Pre-incident conditions

The 5A3 and 5A5 lines between Wollar and Mount Piper share common towers (referred to as a double circuit). Prior to the incident, there was the lightning activity in the vicinity of the 5A3 and 5A5 lines.

As there has been no history of a simultaneous trip of both 5A3 and 5A5 lines due to lightning, AEMO was not required to reclassify simultaneous trip of the 5A3 and 5A5 lines prior to the incident.

2.2 The incident

At 0519 hrs on 17 February 2020, the 5A3 and the 5A5 lines simultaneously tripped and successfully auto reclosed after 15 seconds.

¹ See NER clause 4.8.15(a)(1)(i), as the event relates to a non-credible contingency event; and the AEMC Reliability Panel Guidelines for Identifying Reviewable Operating Incidents.

² See NER clause 4.8.15(b).

³ AEMO categorise double circuit transmission lines as Possible, Probable or Proven with respect of the likelihood of lightning trip – AEMO, Power System Security Guidelines, Section 8.4.

⁴ TransGrid is the Transmission Network Service Provider (TNSP) for New South Wales.

2.3 TransGrid investigation

The following is based on information provided by TransGrid.

2.3.1 Trip of 5A3 and 5A5 lines

Both faults on the 5A3 and the 5A5 lines were caused by a white phase to earth fault. Distance to fault locations indicated that the faults were at approximately 37 km from Mount Piper.

TransGrid advised that there was a single lightning strike near the fault location on the 5A3 and 5A5 lines at the time of the incident. The single lightning strike had an approximate magnitude of 45 kA, compared to typical magnitudes of 10 kA to 20 kA.

Protection detected the earth fault and operated correctly and as expected to clear the fault.

Aerial patrols have since been carried out on the 5A3 and 5A5 lines. This was completed during the last week of February 2020, and TransGrid advised that no obvious signs of damage on insulators or on the transmission lines were observed.

3. Power system security

AEMO is responsible for power system security in the NEM. This means AEMO is required to operate the power system in a secure operating state to the extent practicable and take all reasonable actions to return the power system to a secure state following a contingency event in accordance with the NER⁵.

The power system was in a secure operating state throughout this incident. No action was required by AEMO to restore or maintain power system security.

3.1 Reclassification

AEMO assessed whether to reclassify this incident as a credible contingency event⁶.

As TransGrid could not determine the cause(s) of the incident, AEMO determined that a simultaneous trip of the 5A3 and 5A5 lines was likely to reoccur and correctly reclassified the simultaneous loss of the 5A3 and 5A5 transmission lines as a credible contingency from 0700 hrs on 17 February 2020. This reclassification was cancelled at 2140 hrs on 17 February 2020 as there was no longer lightning activity in the vicinity of the lines.

AEMO now considers the 5A3 and the 5A5 lines as vulnerable transmission lines with a category of probable due to lightning.

4. Market information

AEMO is required by the NER and operating procedures to inform the market about incidents as they progress. This section assesses how AEMO informed the market⁷ over the course of this incident.

⁵ Refer to AEMO's functions in section 49 of the National Electricity Law and the power system security principles in clause 4.2.6 of the NER.

⁶ AEMO is required to assess whether or not to reclassify a non-credible contingency event as a credible contingency event – NER clause 4.2.3A(c) – and to report how the reclassification criteria were applied – NER clause 4.8.15(ca).

⁷ AEMO generally informs the market about operating incidents as the progress by issuing Market Notices – see <https://www.aemo.com.au/Market-Notices>.

For this incident, AEMO informed the market on the following matters:

1. A non-credible contingency event – notify within two hours of the event⁸.
 - AEMO issued Market Notice 74180 at 0543 hrs on 17 February 2020, 24 minutes after the event, to advise of the non-credible contingency event.
2. Reclassification, details, and cancellation of a non-credible contingency – notify as soon as practical⁹.
 - AEMO issued Market Notice 74182 at 0701 hrs on 17 February 2020 to advise that AEMO was not satisfied that this non-credible event is unlikely to reoccur, and would therefore reclassify this event as a credible contingency event when lightning is in the vicinity.
 - AEMO issued Market Notice 74183 at 0701 hrs on 17 February 2020 to advise that AEMO now considered the 5A3 and the 5A5 lines as vulnerable transmission lines with a category of Probable due to lightning.
 - AEMO issued Market Notice 74184 at 0711 hrs on 17 February 2020 to advise that AEMO had reclassified the incident as a credible contingency.
 - AEMO issued Market Notice 74237 at 2141 hrs on 17 February 2020 to advise that the reclassification of the simultaneous trip of the 5A3 and the 5A5 lines had been cancelled, because a reoccurrence of the incident was no longer reasonably possible.

5. Conclusions

AEMO has assessed this incident in accordance with clause 4.8.15(b) of the NER. In particular, AEMO has assessed the adequacy of the provision and response of facilities or services, and the appropriateness of actions taken to restore or maintain power system security.

AEMO has concluded that:

1. The trip of the 5A3 and the 5A5 lines was due to lightning, and all protections operated as designed and as expected to clear the fault.
2. AEMO correctly reclassified the simultaneous trip of the 5A3 and the 5A5 lines as a credible contingency after the incident.
3. AEMO now considers the 5A3 and the 5A5 lines to be vulnerable transmission lines with a category of Probable due to lightning.
4. The power system remained in a secure operating state throughout this incident.

⁸ AEMO is required to notify the market of a non-credible contingency event within two hours of the event – AEMO, Power System Security Guidelines, Section 7.3.

⁹ AEMO is required to notify the market of a reclassification – NER clause 4.2.3(g), details of the reclassification – 4.2.3(c), and when AEMO cancels the reclassification – 4.2.3(h).

A1. System diagram

The diagram below provides an overview of the 5A3 and 5A5 lines and where the faults occurred due to the single lightning strike shown by a red oval.

Figure 1 An overview of the 5A3 and 5A5 lines

