



Frequency and Time Error Monitoring – 3rd Quarter 2018

April 2019

For the National Electricity Market

PURPOSE

AEMO has prepared this document to provide information about the frequency and time error performance in the National Electricity Market Mainland and Tasmania regions for the period July to September 2018 inclusive.

DISCLAIMER

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies. AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.

Contents

1.	Introduction	5
2.	Operation within the Normal Operating Frequency Band	6
3.	Events outside the Normal Operating Frequency Excursion Band	8
4.	Events Outside the Frequency Operating Standards	11
4.1	Mainland Events	11
4.1.1	NSW-QLD interconnector trip on the 25 th August 2018	12
4.2	Tasmanian Events	13
4.2.1	Basslink operation on the 13 th August 2018	13
5.	Accumulated Time Error	14
6.	Area Control Error	16

Tables

Table 1	Mainland and Tasmania: Frequency excursions outside the NOFEB and returned in FOS timeframes.....	8
Table 2	Mainland and Tasmania: Frequency excursions outside the NOFEB not returned in FOS timeframes.....	9
Table 3	Mainland frequency events outside the FOS.....	11
Table 4	Power system incidents causing frequency deviations.....	12
Table 5	Tasmania frequency events outside the FOS.....	13
Table 6	Maximum and Minimum time error measurements for mainland and Tasmania.....	14

Figures

Figure 1	Minimum 30-Day rolling average of percentage of time mainland and Tasmania frequencies remained within NOFB from October 2017 to September 2018	6
Figure 2	Mainland frequency distribution	7
Figure 3	Tasmania frequency distribution	7
Figure 4	Regional frequency during the separation events on the 25 th August 2018.....	13
Figure 5	Time error constraint active in Mainland.....	14
Figure 6	Time error constraint active in Tasmania	15
Figure 7	Minimum and maximum ACE per DI in mainland.....	16
Figure 8	Minimum and maximum ACE per DI in Tasmania	17

1. Introduction

AEMO must use reasonable endeavours to maintain power system frequency and time error within the limits specified by the Reliability Panel in the Frequency Operating Standards (FOS)¹ for the mainland and Tasmanian regions. This document reports on the frequency and time error performance observed during July, August and September 2018 in all regions of the National Electricity Market (NEM). Queensland, New South Wales, Victoria and South Australia are referred to as the 'mainland' throughout the report.

The Power System Frequency and Time Deviation Monitoring Report – Reference Guide² outlines the calculation procedure used by AEMO to produce the quarterly Frequency and Time Error Monitoring report.

The analysis of the delivery of Slow Raise, Slow Lower, Delayed Raise and Delayed Lower Frequency Controlled Ancillary Services (FCAS) presented in this report are based on 4-second SCADA information derived from AEMO's systems. Unless otherwise noted, frequency data for the mainland is sourced from 4-second measurements in New South Wales and frequency data for Tasmania is sourced from 4-second measurements in Tasmania.

¹ <https://www.aemc.gov.au/australias-energy-market/market-legislation/electricity-guidelines-and-standards/frequency-0>

² <http://www.aemo.com.au/Electricity/National-Electricity-Market-NEM/Security-and-reliability/Ancillary-services/Frequency-and-time-error-monitoring>

2. Operation within the Normal Operating Frequency Band

Clause A.1.2(b) of the FOS requires that in the absence of a contingency event, AEMO should maintain system frequency within the applicable normal operating frequency excursion band, and should not exceed the applicable normal operating frequency band for more than five minutes on any occasion and not for more than 1% of the time over any 30 day period³.

Frequency performance in the mainland met this requirement for Quarter 3 2018.

Frequency performance in Tasmania did not meet this requirement for Quarter 3 2018.

AEMO calculates the percentage of time spent inside the NOFB on a daily rolling average. The minimum of these 30-day averages observed within each month is reported in Figure 1. The figure shows statistics both including and excluding data during contingency events.




Figure 1 Minimum 30-Day rolling average of percentage of time mainland and Tasmania frequencies remained within NOFB from October 2017 to September 2018

The frequency distribution over Quarter 3 2018 is shown in Figure 2 and Figure 3.

³ <https://www.aemc.gov.au/sites/default/files/content/c2716a96-e099-441d-9e46-8ac05d36f5a7/REL0065-The-Frequency-Operating-Standard-stage-one-final-for-publi.pdf>




Figure 2 Mainland frequency distribution




Figure 3 Tasmania frequency distribution

3. Events outside the Normal Operating Frequency Excursion Band

Table 1 and Table 2 summarise the events in the mainland and Tasmania with frequency excursions outside the Normal Operating Frequency Excursion Band (NOFEB)⁴.

For all mainland and Tasmania events listed in 0, frequency returned to the NOFB within the times specified in the FOS. For the events in Table 2, it did not. These events are discussed further in Section 4.

Table 1 Mainland and Tasmania: Frequency excursions outside the NOFEB and returned in FOS timeframes

Event	Low/High/Both Frequency Event	Number of Events	
		Mainland	Tasmania
No contingency or load event noted	LOW	0	17
	HIGH	0	36
	BOTH	0	1
Load Event	LOW	1	27
	HIGH	0	102
	BOTH	0	24
Generation Event	LOW	5	15
	HIGH	0	3
	BOTH	0	0
Network Event	LOW	0	0
	HIGH	0	0
	BOTH	0	0

⁴ Frequency range of 49.75 Hz – 50.25 Hz

Event	Low/High/Both Frequency Event	Number of Events	
		Mainland	Tasmania
Separation Event	LOW	0	0
	HIGH	0	0
	BOTH	0	0
Multiple Contingency Event	LOW	0	0
	HIGH	0	0
	BOTH	0	0

Table 2 Mainland and Tasmania: Frequency excursions outside the NOFEB not returned in FOS timeframes

Event	Low/High/Both Frequency Event	Number of Events	
		Mainland	Tasmania
No contingency or load event noted	LOW	0	6
	HIGH	0	0
	BOTH	0	1
Load Event	LOW	0	1
	HIGH	0	0
	BOTH	0	2
Generation Event	LOW	1	3
	HIGH	0	0
	BOTH	0	0
Network Event	LOW	0	0
	HIGH	0	0
	BOTH	0	0

Event	Low/High/Both Frequency Event	Number of Events	
		Mainland	Tasmania
Separation Event	LOW	0	0
	HIGH	0	0
	BOTH	1	0
Multiple Contingency Event	LOW	0	0
	HIGH	0	0
	BOTH	0	0

4. Events Outside the Frequency Operating Standards

This section analyses the events identified as not meeting the standards in the FOS.

4.1 Mainland Events

Twenty-two frequency events were recorded in the mainland that did not meet the FOS during this reporting period. This occurred due to the event duration, or where the frequency was outside the NOFEB for a reason other than a contingency event or a load event. For most situations, the FOS requires that frequency should not remain outside the NOFB for more than 300 seconds. Mainland frequency events exceeding FOS restoration timeframes are listed in Table 3.

Table 3 Mainland frequency events outside the FOS

Event	Number of Events	Min/Max Mainland Frequency (Hz)	Duration outside NOFB - 49.85 – 50.15 Hz (sec) for min/max frequency
Generation Events	5	49.67	372
Load events	2	50.16	316
No contingency or load event	14	49.75 50.16	380
Separation Event	1	49.01 50.67	816 ⁵

Following the generation and load events, the frequency was contained between 49.5Hz to 50.5Hz but was not stable within the NOFB in less than or equal to 5 minutes.

On 16 occasions when there were no reported contingency or load events, the frequency exceeded the NOFB but was not stable and did not recover within 5 minutes. However, the frequency was always contained within the NOFEB.

More information on power system incidents causing large frequency deviations can be found in Table 4:

⁵ Time outside NOFB observed in Queensland following the QNI trip

Table 4 Power system incidents causing frequency deviations

Event Date and Time	Min Frequency (Hz)	Max Frequency (Hz)	Cause for the Event	Time outside NOFB (s)
Monday 13 th August 2018 2043 hrs	MAIN: 49.65 Hz TAS: 48.78 Hz	N/A	Loy Yang A2 trip	200
Saturday 25 th August 2018 1311 hrs	NSW/VIC: 49.02 Hz QLD: 49.75 Hz SA: 49.20 Hz TAS: 48.74	NSW/VIC: 50.12 Hz QLD: 50.87 Hz SA: 50.46 Hz TAS: 50.20 Hz	NSW-QLD interconnector (QNI) trip	816 ⁵
Thursday 6 th September 2018 0202 hrs	MAIN: 49.67 Hz TAS: 48.96 Hz	N/A	Loy Yang A1 trip	192
Thursday 6 th September 2018 1244 hrs	MAIN: 49.64 Hz TAS: 48.63 Hz	N/A	Loy Yang A1 trip	184

4.1.1 NSW-QLD interconnector trip on the 25th August 2018

On the 25th August 2018, the QNI interconnector between QLD and NSW tripped due to lightning. Immediately prior to the trip 857 MW was flowing south into NSW. 8 seconds after the QNI trip, the Heywood interconnector between SA and VIC opened, due to action of a control scheme. Immediately prior to the event, 165 MW was flowing east into VIC.

While no large generation unit disconnected as a result of this incident, the combined loss of supply for the VIC-NSW island was 1022 MW.

This incident resulted in a total of 1100.5 MW of load disconnection; 741.5 MW in NSW via UFLS, 278 MW in VIC via UFLS and 81 MW in TAS via contracted control scheme action.

Figure 4 below shows the frequency observed in each region during the event. This figure is from the Preliminary report - Queensland and South Australia system separation on 25 August 2018 report⁶.

⁶ <https://www.aemo.com.au/-/media/Files/Electricity/NEM/Market Notices and Events/Power System Incident Reports/2018/Preliminary-report-QLD-SA-System-Separation-25-August-2018.pdf>




Figure 4 Regional frequency during the separation events on the 25th August 2018

4.2 Tasmanian Events

Sixty-four frequency events were recorded in Tasmania that did not meet FOS restoration requirements occurred during this reporting period. These events are listed in Table 5.

Table 5 Tasmania frequency events outside the FOS

Event	Number of Events	Min/Max Tasmanian Frequency (Hz)	Duration outside NOFB - 49.85 – 50.15 Hz (sec) for min/max frequency
Frequency outside the NOFEB for reason other than a contingency event or a load event	64	48.94 50.86	176

Following the generator and load events, the frequency was contained between 48.0Hz to 52.0Hz and recovered within the FOS timeframe of 10 minutes.

On 64 occasions when there were no reported contingency or load events, the frequency exceeded the NOFEB. Out of the 64 occasions, there were 8 cases when the frequency was not stable and did not recover within 5 minutes.

4.2.1 Basslink operation on the 13th August 2018

There was a power system incident on Monday 13th August 2018 that was initiated by the trip of Loy Yang A2. As a result of the outage, the frequency in Mainland dropped to 49.65 Hz. Basslink responded rapidly and the frequency in Tasmania dropped to 48.78 Hz, which is below the trigger level (48.8 Hz) of the AUFLS2 scheme. As a consequence, the AUFLS2 scheme caused 100 MW of load shedding to occur at Nyrstar. The Basslink control scheme operated as expected, with Basslink supplying frequency support above its normal market rating of 480 MW for a brief period.

5. Accumulated Time Error

The FOS specify that the accumulated time error should be maintained within the range ± 15 seconds in the mainland and Tasmania. Constraint equations used to control mainland accumulated time error by varying the amount of Regulation FCAS enabled, are based on measurements taken in Queensland and New South Wales. The ranges of accumulated time error recorded for measurements in mainland and Tasmania are provided in Table 6.

Table 6 Maximum and Minimum time error measurements for mainland and Tasmania

Value	Mainland	Tasmania
Highest positive time error (seconds)	14.72	7.91
Lowest negative time error (seconds)	-4.93	-17.04

Figure 5 and 6 below show the percentage of time that the time error has been less than or greater than 1.5 seconds and the Area Control Error Regulation was increased accordingly due to the time error constraint being active.




Figure 5 Time error constraint active in Mainland




Figure 6 Time error constraint active in Tasmania

6. Area Control Error

As per the Regulation FCAS Contribution Factors Procedure⁷, AEMO first calculates an area control error (ACE), representing the MW equivalent size of the current frequency deviation and accumulated frequency deviation (time error) of the system.

EQ. 1
$$ACE = 10 \cdot Bias \cdot (F - FS - FO)$$

Where:

- (i) Bias is the area frequency bias and is a tuned value that represents the conversion ratio between MW and 0.1Hz of frequency deviation;
- (ii) F is the current measured system frequency;
- (iii) FS is the scheduled frequency (50.0Hz); and
- (iv) FO is a frequency offset representing accumulated frequency deviation, i.e. time error.

Figure 7 and 8 show a comparison of the minimum and maximum ACE per dispatch intervals in the mainland and Tasmania in the last quarter.




Figure 7 Minimum and maximum ACE per DI in mainland

⁷ http://www.aemo.com.au/-/media/Files/Electricity/NEM/Security_and_Reliability/Ancillary_Services/Regulation-FCAS-Contribution-Factors-Procedure.pdf




Figure 8 Minimum and maximum ACE per DI in Tasmania