



Monthly Constraint Report

February 2021

A report for the National Electricity Market

Important notice

PURPOSE

This publication has been prepared by AEMO to provide information about constraint equation performance and related issues, as at the date of publication.

DISCLAIMER

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies. AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.

Contents

1.	Introduction	5
2.	Constraint Equation Performance	5
2.1	Top 10 binding constraint equations	5
2.2	Top 10 binding impact constraint equations	6
2.3	Top 10 violating constraint equations	7
2.4	Top 10 binding interconnector limit setters	8
2.5	Constraint Automation Usage	9
2.6	Binding Dispatch Hours	9
2.7	Binding Constraint Equations by Limit Type	11
2.8	Binding Impact Comparison	11
2.9	Pre-dispatch RHS Accuracy	12
3.	Generator / Transmission Changes	14
3.1	Constraint Equation Changes	14

Tables

Table 1	Top 10 binding network constraint equations	5
Table 2	Top 10 binding impact network constraint equations	6
Table 3	Top 10 violating constraint equations	7
Table 4	Reasons for constraint equation violations	7
Table 5	Top 10 binding interconnector limit setters	8
Table 6	Top 10 largest Dispatch / Pre-dispatch differences	12
Table 7	Generator and transmission changes	14

Figures

Figure 1	Interconnector binding dispatch hours	10
Figure 2	Regional binding dispatch hours	10
Figure 3	Binding by limit type	11
Figure 4	Binding Impact comparison	12

Figure 5 Constraint equation changes 15

Figure 6 Constraint equation changes per month compared to previous two years 15

1. Introduction

This report details constraint equation performance and transmission congestion related issues for February 2021. Included are investigations of violating constraint equations, usage of the constraint automation and performance of Pre-dispatch constraint equations. Transmission and generation changes are also detailed along with the number of constraint equation changes.

2. Constraint Equation Performance

2.1 Top 10 binding constraint equations

A constraint equation is binding when the power system flows managed by it have reached the applicable thermal or stability limit or the constraint equation is setting a Frequency Control Ancillary Service (FCAS) requirement. Normally there is one constraint equation setting the FCAS requirement for each of the eight services at any time. This leads to many more hours of binding for FCAS constraint equations - as such these have been excluded from the following table.

Table 1 Top 10 binding network constraint equations

Constraint Equation ID (System Normal Bold)	Description	#Dis (Hours)	Change Date
S>NIL_MHNW1_MHN W2	Out= Nil, avoid O/L Monash-North West Bend #2 132kV on trip of Monash-North West Bend #1 132kV line, Feedback	2718 (226.5)	29/09/2020
N^^N_NIL_3	Out= Nil, limit power flow on line X5 from Balranald to Darlington Point (X5) to avoid voltage collapse for contingency trip of Bendigo-Kerang 220kV line in NW Victoria	1758 (146.5)	24/02/2021
N^^N_NIL_2	Out=Nil , limit Darlington Point to Wagga line (63) line flow to avoid voltage collapse at Darlington Point 132kV post contingency trip of line 63, Feedback	1563 (130.25)	24/02/2021
V^^N_NIL_1	Out = Nil, avoid voltage collapse around Murray for loss of all APD potlines	1542 (128.5)	11/02/2021
N>>N-NIL_94T_947	Out= Nil, avoid O/L Molong to Orange North (94T) on trip of Wellington to Orange North (947), Feedback	1079 (89.91)	2/03/2021
N^^Q_NIL_B1	Out= Nil, avoid Voltage Collapse on loss of Kogan Creek	1009 (84.08)	6/12/2017
V>V_NIL_17	Out = NIL, prevent pre-contingent overload of Wemen 220/66 kV txfmr, flow from 66 kV to 220 kV, feedback	829 (69.08)	29/09/2020
V_VS_LB_CAN_50	Limit Heywood + Lake Bonney WF + Canunda WF <= 50 MW for system strength requirement when SA is at risk of separation.	730 (60.83)	17/08/2020
V_S_NIL_ROCOF	Out = NIL, limit VIC to SA Heywood interconnection flow to prevent Rate of Change of Frequency exceeding 2 Hz/sec in SA immediately following loss of	676 (56.33)	9/10/2020

Constraint Equation ID (System Normal Bold)	Description	#DIs (Hours)	Change Date
	Heywood interconnector. [NOTE: Switches based on ON/OFF status of Dalry Battery in Load Mode]]		
T_MRWF_FOS	Limit Musselroe wind farm due to upper limit on Tasmanian generator events. Limit is 153 MW (effective 144 MW at the connection point at Derby)	467 (38.91)	1/01/2020

2.2 Top 10 binding impact constraint equations

Binding constraint equations affect electricity market pricing. The binding impact is used to distinguish the severity of different binding constraint equations.

The binding impact of a constraint is derived by summarising the marginal value for each dispatch interval (DI) from the marginal constraint cost (MCC) re-run¹ over the period considered. The marginal value is a mathematical term for the binding impact arising from relaxing the RHS of a binding constraint by one MW. As the market clears each DI, the binding impact is measured in \$/MW/DI.

The binding impact in \$/MW/DI is a relative comparison and a helpful way to analyse congestion issues. It can be converted to \$/MWh by dividing the binding impact by 12 (as there are 12 DIs per hour). This value of congestion is still only a proxy (and always an upper bound) of the value per MW of congestion over the period calculated; any change to the limits (RHS) may cause other constraints to bind almost immediately after.

Table 2 Top 10 binding impact network constraint equations

Constraint Equation ID (System Normal Bold)	Description	∑ Marginal Values	Change Date
N^^N_NIL_2	Out=Nil , limit Darlington Point to Wagga line (63) line flow to avoid voltage collapse at Darlington Point 132kV post contingency trip of line 63, Feedback	1,443,500	24/02/2021
S>NIL_MHNSW1_MH NW2	Out= Nil, avoid O/L Monash-North West Bend #2 132kV on trip of Monash-North West Bend #1 132kV line, Feedback	892,274	29/09/2020
N^^N_NIL_3	Out= Nil, limit power flow on line X5 from Balranald to Darlington Point (X5) to avoid voltage collapse for contingency trip of Bendigo-Kerang 220kV line in NW Victoria	645,121	24/02/2021
N>>N-MPWW_ONE_8	Out= Mt. Piper to Wallerawang(70 or 71), avoid O/L Molong to Orange North (94T) on trip of the remaining Mt Piper to Wallerawang (71 or 70) , Feedback	643,829	2/03/2021
V>V_NIL_17	Out = NIL, prevent pre-contingent overload of Wemen 220/66 kV txfmr, flow from 66 kV to 220 kV, feedback	483,784	29/09/2020
N>>N-NIL_94T_947	Out= Nil, avoid O/L Molong to Orange North (94T) on trip of Wellington to Orange North (947), Feedback	405,974	2/03/2021
S_NIL_STRENGTH_1	Upper limit (1300 to 1750 MW) for South Australian non-synchronous generation for minimum synchronous generators online for system strength requirements. Automatically swamps out when required HIGH combination is online.	395,839	19/08/2020
Q>NIL_COLNVSF1	Out = Nil, Limit Collinsville Solar Farm to thermal rating of Powerlink's RMU	328,002	5/11/2019

¹ The MCC re-run relaxes any violating constraint equations and constraint equations with a marginal value equal to the constraint equation's violation penalty factor (CVP) x market price cap (MPC). The calculation caps the marginal value in each DI at the MPC value valid on that date. MPC is increased annually on 1st July.

Constraint Equation ID (System Normal Bold)	Description	Σ Marginal Values	Change Date
SA_ISLE_STRENGTH_B U	Maximum limit (130 MW) for Bungala Solar Farm for system strength requirements when SA is at risk of separation or when islanded.	275,246	13/09/2019
F_T_AUFLS2_R6	TAS AUFLS2 control scheme. Limit R6 enablement based on loaded armed for shedding by scheme.	162,925	4/05/2018

2.3 Top 10 violating constraint equations

A constraint equation is violating when NEMDE is unable to dispatch the entities on the left-hand side (LHS) so the summated LHS value is less than or equal to, or greater than or equal to, the right-hand side (RHS) value (depending on the mathematical operator selected for the constraint equation). The following table includes the FCAS constraint equations. Reasons for the violations are covered in 2.3.1.

Table 3 Top 10 violating constraint equations

Constraint Equation ID (System Normal Bold)	Description	#DIs (Hours)	Change Date
NSA_V_NPSD_100	Newport unit >= 100 MW for Network Support Agreement	12 (1.0)	21/12/2018
F_T+NIL_MG_RECL_R 6	Out = Nil, Raise 6 sec requirement for a Tasmania Reclassified Woolnorth Generation Event (both largest MW output and inertia), Basslink unable to transfer FCAS	8 (0.66)	2/12/2016
F_T_AUFLS2_R6	TAS AUFLS2 control scheme. Limit R6 enablement based on loaded armed for shedding by scheme.	3 (0.25)	4/05/2018
Q_STR_MEWF_ZERO	Limit 0MW to Mt Emerald Wind farm for system strength requirement	3 (0.25)	12/01/2021
F_T+NIL_WF_TG_R6	Out= Nil, Tasmania Raise 6 sec requirement for loss of a Smithton to Woolnorth or Norwood to Scotsdale tee Derby, Waddamana to Cattle Hill or Pieman to Granville Harbour line, Basslink unable to transfer FCAS	2 (0.16)	23/12/2020
F_TASCAP_RREG_022 0	Mainland Raise Regulation Requirement, Cap Tas contribution to 50 MW	1 (0.08)	16/05/2019
VSML_080	Vic to SA on ML upper transfer limit of 80 MW	1 (0.08)	8/01/2014
F_TASCAP_LREG_021 0	Mainland Lower Regulation Requirement, Cap Tas contribution to 50 MW	1 (0.08)	16/05/2019
NC_S_BNGSF2	Non Conformance Constraint for Bungala #2 Solar Farm	1 (0.08)	22/03/2019

2.3.1 Reasons for constraint equation violations

Table 4 Reasons for constraint equation violations

Constraint Equation ID (System Normal Bold)	Description
NSA_V_NPSD_100	Constraint equation violated for 12 consecutive DIs on 14/02/2021 from 1105 hrs to 1200 hrs with max violation of 95 MW occurring at 1125 hrs and 1130 hrs. Constraint equation violation occurred due to Newport PS being limited by its start-up profile.

Constraint Equation ID (System Normal Bold)	Description
F_T+NIL_MG_RECL_R6	Constraint equation violated for 8 non-consecutive DIs on 05/02/2021, 08/02/2021, 09/02/2021 and 26/02/2021 with max violation of 13.23 MW occurring on 08/02/2021 at 1540 hrs. Constraint equation violation occurred due to Tasmania raise 6-second service availability being less than the requirement.
F_T_AUFLS2_R6	Constraint equation violated for 3 DIs on 09/02/2021 at 0735 hrs and 0750 hrs and on 26/02/2021 at 0955 hrs with max violation of 52.42 MW occurring on 09/02/2021 at 0735 hrs. Constraint equation violation occurred due to Tasmania raise 6-second service availability being less than the requirement.
Q_STR_MEWF_ZERO	Constraint equation violated for 3 DIs on 16/02/2021 at 1905 hrs and on 23/02/2021 at 1605 hrs and 1610 hrs with violation degree of 0.001 MW. Constraint equation violation occurred due to Emerald Wind farm exceeding MVar Limit.
F_T+NIL_WF_TG_R6	Constraint equation violated for 2 DIs on 22/02/2021 at 0935 hrs and 1015 hrs with max violation of 3.96 MW occurring at 1015 hrs. Constraint equation violation occurred due to Tasmania raise 6-second service availability being less than the requirement.
F_TASCAP_RREG_0220	Constraint equation violated for 1 DI on 16/02/2021 at 1640 hrs with violation degree 27.91 MW. Constraint equation violated due to SCADA failure.
VSML_080	Constraint equation violated for 1 DI on 11/02/2021 at 1105 hrs with violation degree 26 MW. Constraint equation violated due to competing requirement with the import constraint V>>V_NIL_14.
F_TASCAP_LREG_0210	Constraint equation violated for 1 DI on 16/02/2021 at 1640 hrs with violation degree 4.83 MW. Constraint equation violated due to SCADA failure.
NC_S_BNGSF2	Constraint equation violated for 1 DI on 05/02/2021 at 0855 hrs with violation degree of 0.13 MW. Constraint equation violation occurred due to Bungala #2 Solar farm non conforming.

2.4 Top 10 binding interconnector limit setters

Binding constraint equations can set the interconnector limits for each of the interconnectors on the constraint equation left-hand side (LHS). Table 5 lists the top (by binding hours) interconnector limit setters for all the interconnectors in the NEM and for each direction on that interconnector.

Table 5 Top 10 binding interconnector limit setters

Constraint Equation ID (System Normal Bold)	Interconnector	Description	#DIs (Hours)	Average Limit (Max)
S>NIL_MHNW1_MH_NW2	V-S-MNSP1 Export	Out= Nil, avoid O/L Monash-North West Bend #2 132kV on trip of Monash-North West Bend #1 132kV line, Feedback	2567 (213.92)	162.09 (202.91)
N^^N_NIL_3	VIC1-NSW1 Export	Out= Nil, limit power flow on line X5 from Balranald to Darlington Point (X5) to avoid voltage collapse for contingency trip of Bendigo-Kerang 220kV line in NW Victoria	1718 (143.17)	453.02 (997.41)
V^^N_NIL_1	VIC1-NSW1 Export	Out = Nil, avoid voltage collapse around Murray for loss of all APD potlines	1488 (124.0)	758.7 (1077.8)
F_MAIN++APD_TL_L60	T-V-MNSP1 Import	Out = Nil, Lower 60 sec Service Requirement for a Mainland Network Event-loss of APD potlines due to undervoltage following a fault on MOPS-HYTS-APD 500 kV line, Basslink able to transfer FCAS	1130 (94.17)	-348.09 (-446.0)
N^^N_NIL_3	V-S-MNSP1 Import	Out= Nil, limit power flow on line X5 from Balranald to Darlington Point (X5) to avoid voltage collapse for contingency trip of Bendigo-Kerang 220kV line in NW Victoria	1119 (93.25)	140.77 (-141.81)

Constraint Equation ID (System Normal Bold)	Interconnector	Description	#Dis (Hours)	Average Limit (Max)
N^Q_NIL_B1	NSW1- QLD1 Export	Out= Nil, avoid Voltage Collapse on loss of Kogan Creek	1009 (84.08)	244.92 (425.51)
N^N_NIL_2	V-S- MNSP1 Import	Out=Nil , limit Darlington Point to Wagga line (63) line flow to avoid voltage collapse at Darlington Point 132kV post contingency trip of line 63, Feedback	997 (83.08)	140.57 (-128.81)
F_MAIN++APD_TL_L 5	T-V- MNSP1 Import	Out = Nil, Lower 5 min Service Requirement for a Mainland Network Event- loss of APD potlines due to undervoltage following a fault on MOPS-HYTS-APD 500 kV line, Basslink able to transfer FCAS	948 (79.0)	-376.87 (-446.01)
V^N_NIL_1	V-S- MNSP1 Export	Out = Nil, avoid voltage collapse around Murray for loss of all APD potlines	901 (75.08)	-38.32 (173.95)
F_MAIN++NIL_MG_R 6	T-V- MNSP1 Export	Out = Nil, Raise 6 sec requirement for a Mainland Generation Event, Basslink able transfer FCAS	837 (69.75)	-39.89 (446.0)

2.5 Constraint Automation Usage

The constraint automation is an application in AEMO's energy management system (EMS) which generates thermal overload constraint equations based on the current or planned state of the power system. It is currently used by on-line staff to create thermal overload constraint equations for power system conditions where there were no existing constraint equations or the existing constraint equations did not operate correctly.

The following section details the reason for each invocation of the non-real time constraint automation constraint sets and the results of AEMO's investigation into each case.

Non-real time constraint automation was not used.

2.5.1 Further Investigation


Non-real time constraint automation was not used.

2.6 Binding Dispatch Hours

This section examines the number of hours of binding constraint equations on each interconnector and by region. The results are further categorized into five types: system normal, outage, FCAS (both outage and system normal), constraint automation and quick constraints.


In the following graph the export binding hours are indicated as positive numbers and import with negative values.

Figure 1 Interconnector binding dispatch hours



The regional comparison graph below uses the same categories as in Figure 1 as well as non-conformance, network support agreement and ramping. Constraint equations that cross a region boundary are allocated to the sending end region. Global FCAS covers both global and mainland requirements.


Figure 2 Regional binding dispatch hours



2.7 Binding Constraint Equations by Limit Type

The following pie charts show the percentage of dispatch intervals from for February 2021 that the different types of constraint equations bound.


Figure 3 Binding by limit type



2.8 Binding Impact Comparison

The following graph compares the cumulative binding impact (calculated by summing the marginal values from the MCC re-run – the same as in section 2.2) for each month for the current year (indicated by type as a stacked bar chart) against the cumulative values from the previous two years (the line graphs). The current year is further categorised into system normal (NIL), outage, network support agreement (NSA) and negative residue constraint equation types.

Figure 4 Binding Impact comparison



2.9 Pre-dispatch RHS Accuracy

Pre-dispatch RHS accuracy is measured by the comparing the dispatch RHS value and the pre-dispatch RHS value forecast four hours in the future. The following table shows the pre-dispatch accuracy of the top ten largest differences for binding (in dispatch or pre-dispatch) constraint equations. This excludes FCAS constraint equations, constraint equations that violated in Dispatch, differences larger than ± 9500 (this is to exclude constraint equations with swamping logic) and constraint equations that only bound for one or two Dispatch intervals. AEMO investigates constraint equations that have a Dispatch/Pre-dispatch RHS difference greater than 5% and ten absolute difference which have either bound for greater than 25 dispatch intervals or have a greater than \$1,000 binding impact. The investigations are detailed in 2.9.1.

Table 6 Top 10 largest Dispatch / Pre-dispatch differences

Constraint Equation ID (System Normal Bold)	Description	#DIs	% + Max Diff	% + Avg Diff
V_S_HEYWOOD_UFLS	Out= Nil, Limit Heywood flows when SA under frequency load shedding (UFLS) is insufficient (i.e. when UFLS blocks in SA <1000 MW) to manage for double-circuit loss of Heywood IC.Note: Constraint is swamped if UFLS blocks ≥ 1000 MW.	72	1,879% (9,495)	187% (877)
V_VS_LB_CAN_50	Limit Heywood + Lake Bonney WF + Canunda WF ≤ 50 MW for system strength requirement when SA is at risk of separation.	150	1,685% (33.69)	51.27% (6.57)
V_T_NIL_FCSPS	Basslink limit from Vic to Tas for load enabled for FCSPS	136	1,663% (446.55)	20.13% (36.1)
S>NIL_HUWT_STBG2	Out = Nil; Limit Snowtown WF generation to avoid Snowtown - Bungama line OL on loss of Hummocks - Waterloo line.[Note: Wattle PT trips when generating ≥ 80 MW when Dalymple Battery (i.e. both Gen and Load component) is I/S]	26	273% (137.53)	98.34% (67.55)
V^^SML_NSWRB_2	Out = NSW Murraylink runback scheme, VIC to SA transfer limit on Murraylink to avoid voltage collapse at Red Cliffs for the loss of either the Darlington Point to Balranald (X5) or Balranald to Buronga (X3) 220kV lines	94	143.48% (299.16)	87.31% (203.01)

Constraint Equation ID (System Normal Bold)	Description	#DIs	% + Max Diff	% + Avg Diff
T::T_NIL_1	Out = NIL, prevent transient instability for fault and trip of a Farrell to Sheffield line, Swamp if less than 3 synchronous West Coast units generating or Farrell 220kV bus coupler open or Hampshire 110kV line is closed.	123	135.95% (287.02)	33.36% (98.86)
V::N_SMTT_S2	Out = South Morang to Thomastown 220kV line, prevent transient instability for fault and trip of a HWTS-SMTS 500 kV line, SA accelerates, Yallourn W G1 on 500 kV.	3	133.52% (96.51)	70.48% (88.53)
N>N-NIL_LSDU	Out = Nil, avoid overloading Lismore to Dunoon line (9U6 or 9U7) on trip of the other Lismore to Dunoon line (9U7 or 9U6), Feedback	98	94.2% (63.28)	39.75% (23.4)
N^^V_NIL_1	Out = Nil, avoid voltage collapse at Southern NSW for loss of the largest Vic generating unit or Basslink	14	77.3% (338.76)	42.21% (200.64)
N>>N-MPWW_ONE_8	Out= Mt. Piper to Wallerawang(70 or 71), avoid O/L Molong to Orange North (94T) on trip of the remaining Mt Piper to Wallerawang (71 or 70) , Feedback	46	70.48% (25.75)	15.81% (10.5)

2.9.1 Further Investigation

The following constraint equation(s) have been investigated:

V_S_HEYWOOD_UFLS: Investigated and no improvement can be made to the constraint equation at this stage. Changes to the status of the reactive devices between DS/PD contributes to the PD accuracy.

V_VS_LB_CAN_50: Investigated and no improvement can be made to the constraint equation at this stage.

V_T_NIL_FCSPS: This constraint equation uses analog values for the load enabled for the FCSPS in Pre-dispatch. This value can change quickly in dispatch and this is not possible to predict in Pre-dispatch. No changes proposed.

S>NIL_HUWT_STBG2: Investigated and no improvement can be made to the constraint equation at this stage.

V^^SML_NSWRB_2: Investigated and no improvement can be made to the constraint equation at this stage.

T::T_NIL_1: Investigated and no improvement can be made to the constraint equation at this stage.

N>N-NIL_LSDU: Investigated and the mismatch is due to modelling of DFS and SCADA value on Terranora load. DFS forecasting is being investigated to improve its performance. No improvements can be made to the constraint equation at this stage.

N>>N-MPWW_ONE_8: Investigated and no improvement can be made to the constraint equation at this stage.

3. Generator / Transmission Changes

One of the main drivers for changes to constraint equations is from power system change, whether this is the addition or removal of plant (either generation or transmission). The following table details changes that occurred in for February 2021.

Table 7 Generator and transmission changes

Project	Date	Region	Notes
Morgan-Whyalla Pipeline Pumping Station No 4, PV Units 1-2	2 February 2021	SA1	New Generator
Morgan-Whyalla Pipeline Pumping Station No 2, PV Units 1-2	9 February 2021	SA1	New Generator
Morgan-Whyalla Pipeline Pumping Station No 1, PV Units 1-2	9 February 2021	SA1	New Generator
Corowa Solar Farm	9 February 2021	NSW1	New Generator
Berrybank Wind Farm	16 February 2021	VIC1	New Generator
Marulan 330/132kV No 3 Transformer	17 February 2021	NSW	Replacement transformer for No.4 330/132 kV transformer


3.1 Constraint Equation Changes

The following pie chart indicates the regional location of constraint equation changes. For details on individual constraint equation changes refer to the Weekly Constraint Library Changes Report² or the constraint equations in the MMS Data Model.³

² AEMO. *NEM Weekly Constraint Library Changes Report*. Available at: http://www.nemweb.com.au/REPORTS/CURRENT/Weekly_Constraint_Reports/

³ AEMO. *MMS Data Model*. Available at: <https://www.aemo.com.au/energy-systems/market-it-systems/nem-guides/wholesale-it-systems-software>

Figure 5 Constraint equation changes



The following graph compares the constraint equation changes for the current year versus the previous two years. The current year is categorised by region.

Figure 6 Constraint equation changes per month compared to previous two years

