

Vulnerable Transmission Lines
Updated on: 06/03/2024

Notes:
LTTW: Lightning Trip Time Window
Contact the AEMO Support Hub at supporthub@aemo.com.au or call 1300 236 600 for information on previous changes.

| Region | Double Circuit Transmission Lines | LTTW — End date for Probable state | LTTW — End date for Proven state | Reason for Classification | Category (Probable or Proven) |
|-----------------|--|------------------------------------|----------------------------------|-------------------------------|-------------------------------|
| New South Wales | Bayswater – Mt piper No.5A3 and Mt Piper – Wollar No.5A5 500 kV lines | N/A | 20/10/2027 | Tripped twice in past 3 years | Proven |
| New South Wales | Mt Piper - Bannaby 5A6 500 kV line and Mt Piper - Bannaby 5A7 500 kV line | 6/04/2026 | N/A | Tripped once in past 3 years | Probable |
| Queensland | Ross - Woree No.8905 275 kV line and Cardwell – Tully No.7389 132kV lines | 28/02/2027 | N/A | Tripped once in past 3 years | Probable |
| Queensland | Chalumbin - Turkinjie No. 7165 and 7166 132 kV lines | 25/11/2025 | N/A | Tripped once in past 3 years | Probable |
| Queensland | Collinsville North – Proserpine No.7125 and No.7126 132 kV Lines | N/A | 1/02/2028 | Tripped in past 5 years | Proven |
| Queensland | Collinsville – Stoney Creek No.7306 and Collinsville – Newlands No.7121 132 kV lines | N/A | 15/11/2027 | Tripped twice in past 3 years | Proven |
| Queensland | Ross – Chalumbin No.857 and No.858 275 kV lines | N/A | 21/11/2027 | Tripped twice in past 3 years | Proven |
| Queensland | Strathmore – Clare South no.7208 132 kV line and Strathmore – Clare South (tee King Creek) no.7128 132 kV line | 26/12/2026 | N/A | Tripped once in past 3 years | Probable |
| Tasmania | Farrell–John Butters 220 kV line and Farrell–Rosebery–Newton–Queenstown 110 kV line | N/A | 10/04/2026 | Tripped in past 5 years | Proven |
| Tasmania | Farrell – Reece No.1 and No.2 220 kV lines | N/A | 6/11/2024 | Tripped in past 5 years | Proven |
| Tasmania | Hadspen – Palmerston No.3 & No.4 110 kV lines | 13/12/2026 | N/A | Tripped once in past 3 years | Probable |
| Tasmania | Lindisfarne - Mornington Tee - Rokeby No 1 and 2 110 kV Lines | N/A | 2/01/2028 | Tripped once in past 5 years | Proven |
| Tasmania | Norwood – Scottsdale No. 1 110 kV line and Norwood – Derby – Scottsdale 110 kV line. | 13/02/2027 | N/A | Tripped once in past 3 years | Probable |
| Tasmania | Waddamana - Tungatinah No.1 and No.2 110kV lines | 21/10/2026 | N/A | Tripped once in past 3 years | Probable |
| Victoria | Eildon PS – Mt Beauty No.1 and No.2 220 kV lines | N/A | 14/01/2028 | Tripped in past 5 years | Proven |

Special Reclassification of Transmission Plant during lightning

| Region | Transmission Plant | Notes |
|-----------------|--|--|
| Tasmania | Farrell–Rosebery–Newton–Queenstown 110 kV line | Based on advice from the TasNetworks, the Farrell-Roseberry-Newton-Queens Town 110 kV line is considered at risk of a 3 phase fault when lightning is in the vicinity. As such during periods of lightning activity, AEMO will reclassify a 3 phase fault on this line as a credible contingency. |
| New South Wales | Armidale - Dumaresq 8C and Armidale to Sapphire Wind Farm 8E 330kV lines | Based on the advice from Transgrid, the 8C line is considered at risk of a two-phase to earth fault and the 8E line is considered at risk of a single-phase to earth fault when lightning is in the vicinity. As such during periods of lightning activity, AEMO will reclassify a two-phase to earth fault on 8C and single-phase to earth fault on 8E as a credible contingency. |
| Queensland | Woree - Tumoulin No.877 275 kV and Chalumbin - Turkinje No.7166 132 kV lines | Based on the advice from Powerlink, Woree - Tumoulin No.877 275 kV and Chalumbin - Turkinje No.7166 132 kV is considered at risk of a 3 phase fault when lightning is in the vicinity. While each transmission line is on a separate tower, they have "shared" earthing (underground and aerial) at various locations in the shared easement. As such during periods of lightning activity, AEMO will reclassify a 3 phase fault on these lines as a credible contingency. |
| Queensland | Middle Ridge no.2 and no.3 275/110 kV transformers | Based on advice from Powerlink, Middle Ridge no.2 and no.3 275/110 kV transformers are at risk of tripping simultaneously when lightning is in the vicinity. As such during periods of lightning activity, AEMO will reclassify the trip of both transformers as a credible contingency. |

| | |
|--|--|
| Summary of changes to the previously published version | Removed: - Tungillo - Robertstown 275 kV lines 1 and 2, Robertstown synchronous condensers 1 and 2 from special reclassification of transmission plant during lightning |
|--|--|