

Information to be included in Generator LBSPs

Instructions for completion

Generators must complete relevant Parts of this template depending on all applicable technology and connection categories detailed in Table 1.

All fields in the applicable sections must be filled out. 'Not Applicable' can be used where an item is not relevant to the particular generation facility, however all fields in the applicable sections need to be considered.

Table 1

Section	Embedded Generators	Thermal/Gas Generators	Hydro	TTHL - capable Generators	Wind Generators	Solar Generators	Battery energy storage system	Hybrid Generators	Pumped Hydro
Part A – Information related to all Generators	✓✓	✓	✓✓	✓	✓	✓	✓✓	✓✓	✓✓
Part B – Information related to embedded Generators	✓	(✓)	(✓)	(✓)	(✓)	(✓)	(✓)	(✓)	(✓)
Part C - Information related to asynchronous Generators			(✓)		✓	✓	✓	✓	(✓)
Part D - Information related to TTHL generating units				✓					
Part E- Information related to pumped hydro									✓
Part F – Black start capability options	Optional	Optional	Optional	Optional	Optional	Optional	Optional	Optional	Optional

✓ = Required

(✓) = If applicable

✓✓ = Sections may need to be filled out multiple times for different modes of operation (e.g. generating, pumping, condenser, charging mode etc).

(blank) = unlikely to be required, but must be included if utilised within the plant

Part A

Section 0: LBSP version Information

The following information is to be provided using the table below or equivalent company sheet.

Generation facility	
Version:	
Release Date:	
Approver:	

Section 1: General information on the generation facility

Item	Information required	Include information in this column	
1A	Name of Registered Participant:		
1B	Is the Generator a party to an energy support agreement (refer to the Rules definition)?	(Yes / No) (If yes, include all relevant information associated with the generation facility in section-59)	
1C	Name of the generation facility:		
1D	Address of the generation facility:		
1E	Primary and back up contact for matters relating to local black system procedures ¹		
		Primary Contact	Secondary Contact
		Name	
		Position	
		Phone	
		Email	
1F	Provide the TNSP or DNSP substation where the generator/s connect to the power system.		
1G	Generating unit type:	Choose an item. coal-fired gas-fired CCGT hydro wind solar battery storage system If other or hybrid, please indicate :	
1H	Number and grouping of generating units and MW capacity of each unit:	Number of units: Individual unit capacity: Combined station capacity:	

¹ This field is seeking contact details for personnel that provide and update LBSP information. Any updates to contact details for operational staff e.g. control room personnel or traders, are to be provided to the following email: supporthub@aemo.com.au.

Item	Information required	Include information in this column
1J	Number of generating units that can be returned to service without external supply:	
1K	<p>What are staffing arrangements for the generation facility: staffed 24 hours / staffed during normally working hours / not normally staffed?</p> <p>How is the generation facility operated: operated by staff on site / operated by staff attending site / operated remotely?</p>	

Section 2: Assessment of the situation and safe shut down of generating units

For generation facilities with multiple modes of operation please include information for all relevant modes. For example pumping or condenser modes for hydro systems, and charging mode for battery energy storage systems.

Item	Information required	Include the information in this column
2A	<p>Who would the generation facility staff contact to get an assessment of the situation and the estimated time to receive external power?</p> <p>How would the generation facility staff contact this person/organisation?</p>	
2B	<p>What organisation is responsible for restoring the power system in the vicinity of the generation facility?</p> <p>How would the generation facility staff contact this organisation?</p>	
2C	<p>Following a loss of grid power, do staff need to be called out to shut down or restart units if there are no faults?</p> <p>If faults occur on equipment, do staff need to be called out to manage the situation at the generation facility?</p> <p>If yes, how long will it take to get on-call / standby/ other staff to the generation facility site?</p>	
2D	Is external supply required to safely shut down the generation facility?	
2E	Is there an emergency supply (e.g. diesel, gas turbine, UPS and batteries) installed at the generation facility and how long it can operate independently?	

Item	Information required	Include the information in this column															
	<p>If yes, is it sufficient to safely shut down the generating units and associated plant (e.g. synchronous condenser)?</p> <p>Furthermore, is the backup system capable of barring the units (if required) and maintaining hydraulic pressure for the bearings (if required)?</p>																
2F	<p>How long will it take to safely shutdown, secure and make ready to restart the generating units (e.g. dynamic breaking etc.) and other associated plant (e.g. synchronous condenser)?</p>																
2G	<p>Can the generating units and associated plant (e.g. synchronous condenser) that are in a shutdown sequence be restored to service as soon as external supply becomes available? Or, does the shutdown sequence need to be completed first (e.g. sequence needs to be complete, countdown /timer, temperature, speed, auxiliary etc.)?</p> <p>Please provide information as applicable for the following conditions. Where the following conditions are not applicable to your generation facility, please provide any other conditions which could affect restart of your generating units (and associated plant) during or following the shutdown sequence.</p> <ul style="list-style-type: none"> • Warm (recently shutdown) prior to black system • Hot/online prior to black system • Storage mode, where applicable (such as nitrogen mode) • Charging/pumping/synchronous condenser modes (if applicable) 																
2H	<p>Indicate how the time without external supply following a supply disruption affects the time to restart generating units, under the following scenarios (identify and additional scenarios if applicable)</p> <ul style="list-style-type: none"> • Unit offline and cold/standstill prior to event • Unit offline and warm (recently shutdown) prior to event • Unit warm (was operating prior to event). 	<p>Example only. Please update with applicable scenarios for your generation facility</p> <table border="1" data-bbox="735 1682 1402 2078"> <tr> <td data-bbox="740 1688 900 1839">Time without External Supply:</td> <td data-bbox="904 1688 1032 1839">15 mins</td> <td data-bbox="1037 1688 1165 1839">1 hour</td> <td data-bbox="1169 1688 1297 1839">2 hours</td> <td data-bbox="1302 1688 1398 1839">4 hours</td> </tr> <tr> <td data-bbox="740 1845 900 1906">Scenario</td> <td colspan="4" data-bbox="904 1845 1398 1906">Time to restart units</td> </tr> <tr> <td data-bbox="740 1912 900 2072">Unit offline and cold/standstill prior to event</td> <td data-bbox="904 1912 1032 2072">30 mins to start 1 unit</td> <td data-bbox="1037 1912 1165 2072">30 mins to start 1 unit</td> <td data-bbox="1169 1912 1297 2072">(same as 1 hour offline)</td> <td data-bbox="1302 1912 1398 2072">(same as 1 hour offline)</td> </tr> </table>	Time without External Supply:	15 mins	1 hour	2 hours	4 hours	Scenario	Time to restart units				Unit offline and cold/standstill prior to event	30 mins to start 1 unit	30 mins to start 1 unit	(same as 1 hour offline)	(same as 1 hour offline)
Time without External Supply:	15 mins	1 hour	2 hours	4 hours													
Scenario	Time to restart units																
Unit offline and cold/standstill prior to event	30 mins to start 1 unit	30 mins to start 1 unit	(same as 1 hour offline)	(same as 1 hour offline)													

Item	Information required	Include the information in this column				
	<ul style="list-style-type: none"> Unit in storage mode, where applicable (e.g. nitrogen stored) Unit charging/pumping <p>The required information may be provided in the example table format.</p> <p>Please add additional columns and information if appropriate (e.g. relevant casing temperature limits).</p> <p>If the above scenarios are not applicable to your generation facility, please provide any other scenarios that could affect the time to restart of generating units and associated plant (e.g. synchronous condenser, FACTS device) following a supply disruption.</p> <p>Otherwise include an indication that restart of your generating system is unaffected by the length of time without external supply.</p>		45 mins to start all units	45 mins to start all units		
		Unit offline and warm/recently shutdown prior to event	10 mins to start 1 units 20 mins to start all units	30 mins to start 1 units 45 mins to start all units	(same as 1 hour offline)	(same as 1 hour offline)
		Unit warm/was operating prior to event.	10 mins to start 1 units 20 mins to start all units	30 mins to start 1 units 45 mins to start all units	(same as 1 hour offline)	(same as 1 hour offline)
		Unit in storage mode (as applicable)				
2I	How long can a generating unit(s) and generating system operate without external supply?					

Section 3: Restarting the generating units

For generation facilities with multiple modes of operation please include information for all relevant modes. For example pumping or condenser modes for hydro systems and charging mode for battery energy storage systems.

Item	Information required	Include the information in this column
Electrical Supply To The Station		
3A	<p>Are there any unique/complex switching requirements to receive and transfer station auxiliary supply from the power system (including key protection that requires manual reset and whether the reset requires involvement from external parties)?</p> <p>If there are unique requirements, please specify the details of these requirements.</p>	
3B	Do you need external supply to start a generating unit or the generating system?	

Item	Information required	Include the information in this column
3C	<p>Where does the generation facility receive its external start up supply from?</p> <p>Provide the bus number, feeder and voltage level.</p>	
3D	<p>Energy source used to return units to service without external supply, if different from above.</p>	<p>For example, a diesel generator that can provide electrical supply in the absence of external grid supply.</p>
Other Fuel/Energisation Sources Used By The Station		
3E	<p>What is the fuel supply arrangement, reserve and normal requirements (coal, gas, diesel etc.) to start up and continue to run generating units, or generating system under normal conditions?</p> <p>Identify primary source of fuel supply and any alternative sources of fuel supply, including gas pipelines and coal mines.</p>	<p>(e.g. For starting, LPG from onsite storage used to fire units – sufficient for 8 starts. For continuous operation, coal from nearby mine used for continuous operation – indefinite supply subject to no issues with supply from mine.)</p> <p>(e.g. Units 1&2 are supplied by the Alpha pipeline, Units 3&4 are supplied by the Beta pipeline, Units 5&6 can be supplied by either Alpha or Beta pipelines)</p>
3FG	<p>Are the units dependent on an external fuel supply (other than electricity) to return to service?</p> <p>If not, identify the alternative fuel supplies.</p>	<p>(e.g. Yes, dependent on gas supply to return to service / No, if gas supply is unavailable, fuel oil is available onsite as an alternative fuel supply however the station capacity will be limited to xx MW)</p>
Station Operation and control		
3GH	<p>Can generating units or generating system be connected to a de-energised bus (e.g. dead-bus synchronisation)?</p>	
3H	<p>Can the generating units or generating system operate supplying an isolated load or an island (without a frequency or voltage reference and external supply)?</p> <p>If so, what are the control mode(s) (e.g. voltage and frequency) as well as settings (if different from normal operation) of the generation facility that would be utilised under this condition?</p> <p>Please provide settings of control mode(s) if different from normal operation.</p>	

Item	Information required	Include the information in this column																																																												
	<p>Following restoration of other islands, does the generation facility have facilities to synchronise to the rest of the system?</p> <p>If so, please provide details of the synchronising facilities and its settings (e.g. normal and dead-bus operation, sync point and breaker, voltage levels, paralleling conditions like max. allowable voltage difference, slip and angle limits etc.).</p>																																																													
314	<p>Provide a detailed step-by-step procedure of the restart plan of the generation facility.</p> <p>Include:</p> <ul style="list-style-type: none"> • Specific information about the generation facility that AEMO should be aware of, in developing system restart plans • Switching sequence (can be attached to the LBSP) • The order of unit (and associated plant, for instance synchronous condenser) restarts and estimates of time required to prepare units to synchronise • Procedures for the following conditions where applicable for the generating units and associated plant (e.g. synchronous condenser) <ul style="list-style-type: none"> – Cold/offline prior to black system – Warm (recently shutdown) prior to black system – Hot/online prior to black system – Storage mode (such as nitrogen mode) – Charging/pumping – When operating in synchronous condenser mode 	<p>Example only. Please update with applicable scenarios for your generating system:</p> <p>Restart steps if generating units online prior to the black system</p> <table border="1" data-bbox="639 864 1442 1798"> <thead> <tr> <th>Event</th> <th>Time (mins)</th> <th>Time (running total)</th> <th>Potential Output (MW)</th> <th>Input required (MW)</th> <th>Reason/Notes</th> </tr> </thead> <tbody> <tr> <td colspan="6">Black system (Time=0)</td> </tr> <tr> <td>Safe shutdown</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Restart units (from hot/warm/online state prior to black system)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Initial output available</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Initial ramp</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nominal ramp</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Continuous operation</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table> <p>Restart steps if generating offline units prior to the black system</p> <table border="1" data-bbox="639 1861 1442 2056"> <thead> <tr> <th>Event</th> <th>Time (mins)</th> <th>Time (running total)</th> <th>Potential Output (MW)</th> <th>Input required (MW)</th> <th>Reason/Notes</th> </tr> </thead> <tbody> <tr> <td colspan="6">Black system (Time=0)</td> </tr> </tbody> </table>	Event	Time (mins)	Time (running total)	Potential Output (MW)	Input required (MW)	Reason/Notes	Black system (Time=0)						Safe shutdown						Restart units (from hot/warm/online state prior to black system)						Initial output available						Initial ramp						Nominal ramp						Continuous operation						Event	Time (mins)	Time (running total)	Potential Output (MW)	Input required (MW)	Reason/Notes	Black system (Time=0)					
Event	Time (mins)	Time (running total)	Potential Output (MW)	Input required (MW)	Reason/Notes																																																									
Black system (Time=0)																																																														
Safe shutdown																																																														
Restart units (from hot/warm/online state prior to black system)																																																														
Initial output available																																																														
Initial ramp																																																														
Nominal ramp																																																														
Continuous operation																																																														
Event	Time (mins)	Time (running total)	Potential Output (MW)	Input required (MW)	Reason/Notes																																																									
Black system (Time=0)																																																														

Item	Information required	Include the information in this column					
	<p>- Where the above conditions are not applicable to your generation facility, please provide restart procedures for any other applicable scenarios.</p> <p>The required information may be provided in the example table format (Please add additional columns and rows as appropriate)</p>	Safe shutdown					
		Restart units from standstill/offline/cold state prior to black system					
		Initial output available					
		Initial ramp					
		Nominal ramp					
		Continuous ramp					
3JK	<p>What is the arrangement for supplying of other station essential services? For example demineralised water, instrument air, auxiliaries etc?</p>						
3KL	<p>What nominal capacity steps are available as each unit is progressively brought back on-line?</p> <p>What ramp rates for loading and unloading are available (e.g. for cold/standstill/warm/hot start/storage mode, or as applicable to the generation facility)</p> <p>Provide load curve and time durations (for the above conditions pre black system).</p> <p>Provide a generating unit MW loading capability curve, showing the size of load block as a function of the unit MW output, i.e. load block = f(unit active energy output), or a description of the capability curve (both is preferred)</p> <p>Is there a requirement for the load block to be a discrete value or is there a tolerance range?</p>						

Item	Information required	Include the information in this column
	What are the main factors that dictate these increments?	
3LM	Please advise of any operational loading requirements (such as no go zones between certain MW loading levels, including rough running bands)	
3MN	<p>Please advise if the MVar capability of the generating units differ from normal operation during the various stages of restart (i.e. as a black start unit, initial restart, under islanding conditions)</p> <p>If yes, provide the individual unit and plant specific reactive power capability charts associated with the various stages of restart. Please include a voltage range from e.g. 0.9-1.1pu = f(unit active power output).</p>	
3NQ	<p>Provide the estimated electrical power requirements during various restart stages of the unit (and associated plant, for instance synchronous condensers).</p> <p>Include a breakdown for individual units and plant, an aggregate, and house load where relevant.</p>	
3QP	What is the minimum load requirement for stable operation of each generating unit?	
3PQ	How long can the generation facility operate under minimum loading requirements while system load is being restored, including providing dynamic reactive power support?	
3QR	<p>What are the upper and lower values of the normal operating frequency band for each unit and auxiliary equipment (e.g. pumps, drives, motors etc.) over which full rated output is available?</p> <p>What are the extreme frequency bands for each unit and auxiliary</p>	

Item	Information required	Include the information in this column
	equipment where partial output is available?	
3RS	Please specify the largest size of transformer that can be energised by the generation facility.	
3ST	<p>Are there any special procedures to be followed when energising transformers, such as:</p> <ul style="list-style-type: none"> • any interlocks that must be by-passed etc.? • Soft start capability (include a voltage-time profile) 	
3IU	<p>For transformer energisation:</p> <ul style="list-style-type: none"> • Please provide the soft-start procedure to manage inrush currents when energising transformers and impacts on the generating units(s) as well as its auxiliary equipment • Also, include transformer energisation current capability. Indicate whether generating units/ system can be controlled to minimise transformer magnetising current (e.g. transformer or line charging function, manual control/field current regulator etc.) • Provide the harmonic signature when energising the largest transformer the generating unit can energise 	
3UV	<p>Do you have contingency plan if the generation facility fails during any stage of power system restoration?</p> <p>If so, please provide the contingency plan(s).</p>	

Section 4: Technical details associated with the generation facility

For generation facilities with multiple modes of operation please include information for all relevant modes. For example, pumping or condenser modes for hydro systems and charging mode for battery energy storage systems.

Item	Information required	Include the information in this column
4A	Do the generating units or generating system have under-frequency trip setting/s? If so, provide the settings.	
4B	Do the generating units or generating system have over-frequency (and/or over-speed) trip settings? If so, provide the settings.	
4C	<p>Can the generating units or generating system provide steady state and dynamic voltage control, under emergency and restoration conditions, including when supplying its own auxiliary loads?</p> <p>If so, please specify the voltage control capability under these conditions.</p>	
4D	<p>Can the generating units or generating system provide active power and frequency control capability under emergency and restoration conditions, including when supplying its own auxiliary loads?</p> <p>If so, please specify the active and frequency control capability under these conditions.</p>	
4E	<p>Are there any additional protection settings that would apply during emergency and restoration conditions, including when supplying its own auxiliary loads?</p> <p>If so, please specify the protection settings that would need to apply under these conditions.</p>	
4F	<p>Indicate the fault current that the generation facility can provide during emergency and restoration conditions, including:</p> <ul style="list-style-type: none"> • How long it can be sustained? • Whether the fault current will vary over time? 	

Section 5: Generator participation in energy support or operational arrangements

Item	Information required	Include the information in this column
<p>5A</p> <p>5B</p>	<p>Is the generator a party to an energy support arrangement <u>(refer to Rule definition) that requires this generating system to operate in a particular manner following a major supply disruption?</u></p> <p><u>If yes, include relevant information on the those requirements, including but not limited to: energy support arrangement associated with this generation facility</u></p> <ul style="list-style-type: none"> • <u>Identity of the facility to be supported, and if relevant any specific plant to be supported within the facility.</u> • <u>Active and/or reactive power and minimum number of units of the generating system required to provide the support.</u> • <u>Maximum timeframes to restart/energise the generating system to provide support following a major supply disruption.</u> • <u>Detailed Generator switching sequences/procedures to be undertaken following a major supply disruption under this arrangement.</u> 	
<p>5Bc</p>	<p><u>Are there any operational/network support arrangements in place [as detailed in the Connection and Access Agreement (CAA) or in any other agreement] with a TNSP/ DNSP (including under the connection agreement) requiring this generating system to start and operate in a particular manner following a major supply disruption regarding the starting and operation of generation in a black system condition or major supply disruption?</u></p> <p><u>If yes, please include relevant details such as, but not limited to:</u></p> <ul style="list-style-type: none"> • <u>Details of the purpose of the arrangement (e.g. supplying local load when islanded, black start service).</u> • <u>Active and/or reactive power and minimum number of units of the generating system required to provide the support.</u> 	

	<ul style="list-style-type: none"> • <u>Timeframes to restart/energise to provide support following a major supply disruption/islanding.</u> • <u>Detailed Generator switching sequences/procedures to be undertaken under this arrangement following a major supply disruption/islanding.</u> 	
--	--	--

Section 6: Communication facilities

Item	Information required	Include the information in this column
6A	What communication facilities and provider do you have to communicate with your on-call, standby and other staff, in particular during a major supply disruption (e.g. landline, mobile and/or satellite phone - separate telephone facilities using independent telecommunications service providers)?	
6B	What communication facilities do you have to communicate with AEMO, TNSP and DNSP (include remote and local facilities, where applicable)?	

Part B

Section 7: Restarting embedded generator units

Item	Information required	Include the information in this column
7A	Does the embedded generator have capability to restart and form an island supplying local load or area?	
7B	If an island can be formed, are there facilities for the island to be synchronised to the transmission network at a later stage?	
7DC	If you can provide an SRAS (refer to SRAS guidelines), can you operate under the conditions supplying auxiliary loads while absorbing MVars?	

Part C

Section 8: Asynchronous Generator restart capabilities

For generation facilities with multiple modes of operation please include information for all relevant modes. For example, pumping for asynchronous hydro systems and charging mode for battery energy storage systems.

Item	Information required	Include the information in this column
8A	<p>What are the loading requirements for the generation facility's auxiliaries (where the facility is not black start capable)?</p> <p>Please provide auxiliary requirements as function of kW-Time (such as minimum loading and duration).</p>	
8B	<p>If the generation facility can provide black start capability, what is the supply source for the local auxiliaries?</p>	
8C	<p>Please provide the SCR withstand capability of the generation facility at the connection point.</p>	
8D	<p>Are there any other known limitations when operating during system restoration e.g. X/R?</p>	
8E	<p>Please provide a reactive power capability chart as a function of SCR and X/R at the connection point (if applicable)</p>	
8F	<p>Please specify the voltage and frequency withstand capability of the generation facility during abnormal conditions.</p>	
8G	<p>Would a switchover between control modes/parameters be required between system intact, islanding and restoration conditions?</p> <p>If so,</p> <ul style="list-style-type: none"> • Is the switchover between control modes/parameters automatic (e.g. automatic gain reduction)? Or does the switchover need to be enabled by an operator? • Please provide details of the switchover changes that would apply between system intact, islanding and restoration conditions. Such as the parameters changes that would apply or a summary of the different control modes. 	
8H	<p>Where applicable, please specify details of islanding operation capability.</p>	
8I	<p>Are there any other procedures or arrangement to restart and connect the asynchronous generating units to the power system?</p>	

Part D

Section 9: Use of TTHL capable generating units

Item	Information required	Include the information in this column
9A	Number of generating units capable of tripping to house load (TTHL):	
9B	Are there any limitations on TTHL?	e.g. units are unlikely to successfully TTHL if any of the following apply <ul style="list-style-type: none"> • operating below xx MW • (any other conditions)
9C	How long can the TTHL generating units maintain stable operation on house load?	
9D	If there is a time limit for stable operation following trip to house load, what factors determine this time limit?	
9E	What load blocks are required? (include details of time-frames)	
9F	Are there any other requirements for stable operation supplying house load, until the required load blocks are provided?	

Section 10: Technical details associated with TTHL capable generating units

Item	Information required	Include the information in this column (
10A	What are the triggering mechanisms of the TTHL capable generating units? (include details of the levels, durations, and rates of change of frequency and voltage, and power swings)	
10B	Are the TTHL units fully or partially automated? Is any form of manual intervention required for the generating unit to trip to house load?	
10C	Are there any likely conditions that trip generating units prior to tripping to house load?	
10D	If there are multiple generating units with TTHL capability, how many generating units are normally enabled for TTHL?	

Item	Information required	Include the information in this column (
	What strategy is used in selecting the number of generating units for TTHL?	

Part E

Section 11 Use of Pumped Hydro capable generating units

Item	Information required	Include the information in this column
11A	<p>Please specify the number of generating units capable of operating in pump mode.</p> <p>Please also indicate if the generation facility is single or dual mode operation (pure pumping station or generating & pumping system).</p>	
11B	<p>If there are multiple generating units with pump mode capability, how many units are normally enabled for pump mode?</p> <p>What strategy is used in selecting the number of generating units for pump mode?</p>	
11C	<p>Are there any limitations or dependencies on pump mode operation?</p> <p>Any other known limitations when operating during system restoration e.g. SCR or X/R etc.?</p>	<p>e.g. units are unlikely to successfully operating in pump mode if any of the following apply:</p> <ul style="list-style-type: none"> • operating below/above xx MW load requirement • water level to be between x and y • short circuit ratio or X/R ratio required for stable operation • number of units operating in parallel or single operation • booster pump • any other conditions?
11D	<p>Is restart in pump mode during system restoration possible?</p> <p>If not, what is necessary or required to make the unit restart capable (e.g. plant modification, load requirement etc.)?</p>	
11E	<p>What is the duration or time the generator is capable of stable operation in pump mode?</p> <p>For example, time restrictions, temperature dependencies, cooling, other units to operate in generation mode etc.</p>	
11F	<p>Are there any other requirements for stable operation in pump mode that have an impact on system security or stability?</p>	
11G	<p>Does the generation facility have voltage or frequency control capability (as below) in pump mode?</p>	

Item	Information required	Include the information in this column
	<ul style="list-style-type: none"> • Frequency stabilisation or frequency regulation in pump mode • Primary frequency control, range and setpoints in pump mode • Voltage control mode, range and setpoints in pump mode 	
11H	<p>Please provide time frames/switch over rates for changes between various modes of operation (vice versa):</p> <ul style="list-style-type: none"> • Standstill – Generator mode • Standstill – Pump mode • Condenser – Generator • Condenser – Pump mode • Generator – Pump mode 	
11I	<p>Are load ramp rates customisable for the generation facility in pump mode?</p> <p>If not, please indicate the load blocks of the generation facility in pump mode?</p>	
11J	<p>Is there a difference in operating range between modes?</p> <p>If so, please specify the differences in operating range in pumping mode.</p>	
11K	<p>Is the generation facility capable of voltage or power factor control in pumping mode?</p>	
11L	<p>Can the generation facility follow a specific load target during restart?</p>	
11M	<p>Considering the starting moment required for pumped hydro, is this a limitation during pump mode operation during restoration conditions?</p>	
11N	<p>What are the trip and triggering mechanisms of the pump mode capable generating units?</p> <p>(include details of the levels, durations, frequency and voltage range, rates of change of frequency and voltage, and power swings)</p>	
11O	<p>Are the pump mode units fully or partially automated?</p>	

Item	Information required	Include the information in this column
	Is any form of manual intervention required for the generating unit to operate in pump mode?	

Part F

Section 12: Black start capability options

Item	Information required	Include the information in this column
12A	If the generating units or generation facility are not currently black start capable, please summarise the modifications to equipment, controls or any other relevant changes that would need to be implemented to provide a SRAS (refer to SRAS guidelines).	