



Powerlink Queensland

# Summary of Project Assessment Conclusions Report

9 January 2019

## **Addressing the secondary systems condition risks at Belmont Substation**

### Disclaimer

While care was taken in preparation of the information in this document, and it is provided in good faith, Powerlink accepts no responsibility or liability (including without limitation, liability to any person by reason of negligence or negligent misstatement) for any loss or damage that may be incurred by any person acting in reliance on this information or assumptions drawn from it, except to the extent that liability under any applicable Queensland or Commonwealth of Australia statute cannot be excluded. Powerlink makes no representation or warranty as to the accuracy, reliability, completeness or suitability for particular purposes, of the information in this document.

## Summary

Belmont Substation is located in South East Queensland, approximately eleven kilometres south east of the Brisbane CBD, and forms part of Powerlink's transmission network supplying electricity to the Energex distribution network in the surrounding local area and south of Brisbane.

Several secondary systems at the Belmont Substation are reaching the end of their technical service life and are facing obsolescence with manufacturer support and spares no longer available.

Secondary systems include the control, protection and communications equipment that are necessary to operate the transmission network and prevent damage to primary systems when adverse events occur. Under the National Electricity Rules (the Rules), Transmission Network Service Providers (TNSPs) are required to provide sufficient secondary systems, including redundancies, to ensure the transmission system is adequately protected.

The deteriorated condition and obsolescence issues associated with the Belmont secondary systems presents Powerlink with operational and compliance issues, requiring resolution. Since consideration for this investment is driven by an obligation in the National Electricity Rules (the Rules), it is a 'reliability corrective action' under the Regulatory Investment Test for Transmission (RIT-T).

This Project Assessment Conclusions Report (PACR) represents the final step of the RIT-T process prescribed under the Rules undertaken by Powerlink to address the condition risks arising from ageing and obsolete secondary systems at Belmont Substation. It contains the results of the planning investigation and cost-benefit analysis of credible options. In accordance with the RIT-T, the credible option that maximises the present value of net economic benefits is recommended for implementation.

### Credible options considered

Powerlink identified two credible network options to address the identified need, as presented in Table 1.

Table 1: Summary of credible options

Option	Description	Indicative capital cost (\$million, 2017/18)	Indicative annual O&M costs (\$million, 2017/18)
Base Option: Replacement with new panels in existing building	Replace obsolete secondary system panels within the existing secondary systems building, beginning early 2019 and completed by late 2020	8.6	0.017
Option 1: Replacement with new panels in prefabricated building	Replace obsolete secondary systems using a modular prefabricated building with new secondary systems installed. Installation on site and commissioning to occur by late 2021	9.6	0.017

## Evaluation and conclusion

The RIT-T requires that the proposed preferred option maximises the present value of net economic benefit, or minimises the net cost, to all those who produce, consume and transport electricity in the market.

In accordance with the expedited process for this RIT-T, the Project Specification Consultation Report (PSCR), published in September 2018, made a draft recommendation to implement the Base Option, replacement of obsolete secondary system panels within the free space of the existing secondary systems building, by December 2020. The estimated capital cost of the preferred option is \$8.6 million in 2017/18 prices. Powerlink is the proponent of the proposed network project.

There were no submissions received in response to the PSCR.

As the outcomes of the economic analysis contained in this PACR remain unchanged from those published in the PSCR, the draft recommendation has been adopted without change as the final recommendation, and will now be implemented.



## Contact us

Registered office	33 Harold St Virginia Queensland 4014 Australia
Postal address:	GPO Box 1193 Virginia Queensland 4014 Australia
Contact:	Roger Smith Manager Network and Alternate Solutions
Telephone	(+617) 3860 2328 (during business hours)
Email	<a href="mailto:networkassessments@powerlink.com.au">networkassessments@powerlink.com.au</a>
Internet	<a href="http://www.powerlink.com.au">www.powerlink.com.au</a>