



WEM Procedure: Determination of Market Schedules

Prepared by: AEMO

Document ref:

Version: 232.10

Effective date: 1 April 2024

Status: FINAL-DRAFT

Approved for distribution and use by:

Approved by: Martin Maticka Draft – not approved for distribution or use

Title: Group Manager – WA Operations

Date: 26 March 2024

aemo.com.au

New South Wales | Queensland | South Australia | Victoria | Australian Capital Territory | Tasmania | Western Australia

Australian Energy Market Operator Ltd ABN 94 072 010 327

Version Release History

Version	Effective Date	Summary of Changes
1.0	1 October 2023	First version developed in accordance with clause 7.8.9 of the WEM Rules
2.0	1 April 2024	<ul style="list-style-type: none"> • Addition of capability to propagate Fast Start Modes in Market Schedules. • Addition of capability to propagate forecast charge states for Energy Storage Resources in Market Schedules. • Changes to Fast Start Facility related definitions to align across WEM Procedures. • Minor typographical and formatting fixes.
<u>23.10</u>		<u>Draft for consultation. Amendments made in accordance with AEPC 2024 15.</u>

IMPORTANT NOTICE – EXPLANATORY NOTES

Disclaimer

Explanatory notes included in this document as shaded in-line text are provided for explanatory purposes only to assist comprehension and readability. The information contained in these explanatory notes does not constitute legal or business advice and should not be relied on as a substitute for obtaining detailed advice about the *Electricity Industry Act 2004* (WA), WEM Rules, or any other applicable laws, procedures or policies. AEMO has made reasonable efforts to ensure the quality of the information, but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the explanatory information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.

Contents

1. Introduction	4
1.1. Purpose and scope	4
1.2. Definitions	4
1.3. Interpretation	<u>65</u>
1.4. Related documents	6
2. Market Schedule and scenario determination	<u>87</u>
3. Input Data for Market Schedules	<u>98</u>
3.1. Forecast Unscheduled Operational Demand and variations	<u>98</u>
3.2. Essential System Service requirements	<u>98</u>
3.3. SCADA data and other network data	<u>108</u>
3.4. ESS Trapezia values and Ramp Rates	<u>109</u>
3.5. Unconstrained Injection Forecasts and Unconstrained Withdrawal Forecasts	<u>109</u>
3.6. Other data provided via Real-Time Market Submissions	<u>1140</u>
3.7. Registration data	<u>1140</u>
3.8. Constraint Sets and Constraint Equations	<u>1140</u>
3.9. Dynamic Frequency Control Model and Facility Performance Factors	<u>1240</u>
3.10. Loss Factors	<u>1344</u>
3.11. Constraint Violation Penalties	<u>1344</u>
3.12. ESS Maximum Provision Percentages	<u>1342</u>
3.13. Market Service Price Ceilings and Floors	<u>1342</u>
3.14. Fast Start Facility data	<u>1342</u>
4. Application of Energy Storage Constraints in Market Schedules and Scenarios	<u>1513</u>
Appendix A. Relevant clauses of the WEM Rules	<u>1614</u>

Tables

Table 1	Definitions.....	<u>54</u>
Table 2	Related documents	6
Table 3	Relevant clauses of the WEM Rules	<u>1614</u>

1. Introduction

1.1. Purpose and scope

- 1.1.1. This WEM Procedure: Market Schedules and Scenarios (Procedure) is made in accordance with AEMO's functions under clause 2.1A.2(h) of the Wholesale Electricity Market Rules (WEM Rules).
- 1.1.2. The *Electricity Industry Act 2004*, the WEM Regulations and the WEM Rules prevail over this Procedure to the extent of any inconsistency.
- 1.1.3. In this Procedure, where obligations are conferred on a Rule Participant, that Rule Participant must comply with the relevant obligations in accordance with clause 2.9.7A, 2.9.7D or 2.9.8 of the WEM Rules, as applicable.

AEPC_2024_15 Explanatory Note:

Paragraph 1.1.4(d) has been added to include reference to a requirement of the WEM Rules that is captured under paragraph 3.3.2 of this WEM Procedure, but was inadvertently not listed in previous revisions.

- 1.1.4. The purpose of this Procedure is to document the processes for determining Market Schedules, including:
- (a) ~~t~~The number and types of Scenarios **[clause 7.8.9(a)]**;
 - (b) ~~t~~The principles, methodologies and calculations used to determine:
 - (i) input data for each Market Schedule **[clause 7.8.9(b)(i)]**; and
 - (ii) input data for each Scenario **[clause 7.8.9(b)(ii)]**; and
 - (c) ~~h~~How AEMO will apply clause 7.5.9 to each Market Schedule, including:
 - (i) For each type of Market Schedule **[clause 7.8.9(c)(i)]**; and
 - (ii) ~~Dispatch Intervals or Pre-Dispatch Intervals within each Market Schedule **[clause 7.8.9(c)(ii)]**; and~~
 - (d) ~~any methodology for replacement of erroneous input data or substitution for missing input data **[clause 7.2.5(d)]**.~~
- 1.1.5. Appendix A of this Procedure outlines the head of power clauses that this Procedure is made under, as well as other obligations in the WEM Rules covered by this Procedure.

1.2. Definitions

- 1.2.1. Terms defined in the *Electricity Industry Act 2004*, the WEM Regulations and the WEM Rules have the same meanings in this Procedure unless the context requires otherwise.

AEPC_2024_15 Explanatory Note:

Table 1 has been amended to include a definition for Underlying System Load. The definition has replaced the use of Operational Demand and Forecast Unscheduled Operational Demand in paragraphs 3.9.2 and 3.9.3. The use of Underlying System Load more accurately reflects the inputs of the DFCM, as outlined in WEM Procedure: Essential System Service Quantities.

1.2.2. The following definitions apply in this Procedure unless the context requires otherwise.

Table 1 Definitions

Term	Definition
Constraint Violation Penalty	As defined in WEM Procedure: Dispatch Algorithm Formulation
Dynamic Frequency Control Model	A computer simulation of the SWIS power system frequency that uses an ESS System Configuration as an input and, for a given quantity of RoCoF Control Service, calculates the quantity of Contingency Reserve Raise in response to the Largest Credible Supply Contingency; or Contingency Reserve Lower in response to the Largest Credible Load Contingency, required to maintain the frequency of the SWIS within the Credible Contingency Event Frequency Band.
Energy Management System	The systems used by AEMO to manage the SWIS in real-time.
ESS Maximum Provision Percentage	As defined in WEM Procedure: Essential System Service Quantities
Fast Start Current Mode	As defined in paragraph 2.2.29 of the WEM Procedure: Dispatch Algorithm Formulation
Fast Start Current Mode Time	As defined in paragraph 2.2.30 of the WEM Procedure: Dispatch Algorithm Formulation.
Fast Start Target Mode	As defined in paragraph 2.2.40 of the WEM Procedure: Dispatch Algorithm Formulation.
Fast Start Target Mode Time	As defined in paragraph 2.2.41 of the WEM Procedure: Dispatch Algorithm Formulation.
Historian	A system that archives real-time readings from SCADA.
Initial MW	For a Registered Facility, the level of Injection or Withdrawal in MW at the start of a Dispatch Interval or Pre-Dispatch Interval, as used for the purpose of the Dispatch Algorithm.
Inter Control Centre Protocol	A standard used for control centre communication in the power sector, also known as "IEC 60870/TASE.2".
Primary Dispatch Interval	The first Dispatch Interval in a Dispatch Schedule, from which operative Dispatch Instructions and Market Clearing Prices are determined.
Pure Storage Constraint	As defined in the WEM Procedure: Dispatch Algorithm Formulation.
SCADA	Supervisory Control and Data Acquisition (SCADA) is a system that is used to monitor and control field device(s) at remote locations.
State Estimator	A system that uses a network model to produce estimates of SCADA readings based on other readings in the Network.
<u>Underlying System Load</u>	<u>AEMO's estimate of behind-the-meter demand that is responsive to changes in frequency. Underlying System Load may differ from Forecast Operational Demand due to "behind the meter" and other non-registered generation sources.</u> AEMO's estimate of behind-the-meter demand that is responsive to changes in frequency. Underlying System Load may differ from Forecast Operational Demand due to "behind the meter" and other non-registered generation sources.

1.3. Interpretation

- 1.3.1. The following principles of interpretation apply in this Procedure unless the context requires otherwise.
- (a) Clauses 1.3 to 1.5 of the WEM Rules apply in this Procedure.
 - (b) References to time are references to Australian Western Standard Time.
 - (c) Terms that are capitalised, but not defined in this Procedure, have the meaning given in the WEM Rules.
 - (d) A reference to the WEM Rules or WEM Procedures includes any associated forms required or contemplated by the WEM Rules or WEM Procedures.
 - (e) Words expressed in the singular include the plural and vice versa.
 - (f) A reference to a paragraph refers to a paragraph of this Procedure.
 - (g) A reference to an appendix refers to an appendix of this Procedure.
 - (h) A reference to a clause refers to a clause or section of the WEM Rules.
 - (i) References to WEM Rules in this Procedure in bold and square brackets **[Clause XXX]** are included for convenience only, and do not form part of this Procedure.
 - (j) Text located in boxes and headed as **E[X]** in this Procedure is included by way of explanation only and does not form part of this Procedure. The Procedure prevails to the extent of any inconsistency with the explanatory notes contained within it.
 - (k) The body of this Procedure prevails to the extent of any inconsistency with the figures, diagrams, appendices, schedules, annexures or attachments contained within this document.

1.4. Related documents

- 1.4.1. The documents in Table 2 are associated with this Procedure.

Table 2 Related documents

Reference	Title	Location
WEM Procedure	WEM Procedure: Dispatch Algorithm Formulation	WEM Website
WEM Procedure	WEM Procedure: Forecast Unscheduled Operational Demand	WEM Website
WEM Procedure	WEM Procedure: Adjustment of Real Time Inputs	WEM Website
WEM Procedure	WEM Procedure: Essential System Service Quantities	WEM Website
WEM Procedure	WEM Procedure: Facility Dispatch Process	WEM Website
WEM Procedure	WEM Procedure: Communications and Control Systems	WEM Website

1.5. Communications and provision of information

- 1.5.1. All communication and provision of information by a Market Participant to AEMO under this Procedure must be undertaken via email, unless otherwise specified in this Procedure.
- 1.5.2. All communication and provision of information by AEMO to a Market Participant under this Procedure will be undertaken via email, unless otherwise specified in this Procedure.

DRAFT

2. Market Schedule and scenario determination

AEPC_2024_15 Explanatory Note:

Paragraph 2.1.1 has been amended to include reference to clauses 7.8.4 and 7.8.6A of the WEM Rules to clarify that AEMO will produce Scenarios in accordance with these requirements. Clause 7.8.4 is a new requirement included under the FCESS Cost Review Amending Rules. Clause 7.8.5 is an existing requirement and was not included in paragraph 2.1.1 in the first two revision of the Procedure in error.

2.1.1. AEMO will produce Scenarios as required under clause [7.8.4](#), [7.8.6](#) and [7.8.6A](#).

AEPC_2024_15 Explanatory Note:

Paragraph 2.1.2 has been deleted to remove the requirement for AEMO to produce Dispatch Schedule Scenarios that include In-Service Capacity in Real-Time Market Submissions, and exclude Available Capacity in Real-Time Market Submissions. This change is made in accordance with the removal of clause 7.8.6(a) under the FCESS Cost Review Amending Rules.

~~2.1.2.—In addition to the Scenarios produced under clause 7.8.6, AEMO will produce Dispatch Schedule Scenarios that:~~

- ~~(a) —include In-Service Capacity in Real-Time Market Submissions, and exclude Available Capacity in Real-Time Market Submissions;~~
- ~~(b) —use a higher load forecast than the Reference Scenario; and use a lower load forecast than the Reference Scenario.~~

E[A] Note on projected energy schedules

Paragraphs ~~2.1.22.1.22.1.3~~ and ~~2.1.32.1.32.1.4~~ assume that all Registered Facilities follow their Dispatch Instructions for the purpose of calculating forecast Dispatch Intervals and Pre-Dispatch Intervals.

~~2.1.3.2.1.2.~~ For all Scenarios, for a Dispatch Interval in a Dispatch Schedule except the Primary Dispatch Interval, AEMO will use the cleared energy quantity from the solution to the Dispatch Algorithm in the previous Dispatch Interval as the Initial MW value for that Dispatch Interval.

~~2.1.4.2.1.3.~~ For all Scenarios, for a Pre-Dispatch Interval in a Pre-Dispatch Schedule or Week-Ahead Schedule, except the first Pre-Dispatch Interval in the Pre-Dispatch Schedule or Week-Ahead Schedule, AEMO will use the cleared energy quantity from the previous Pre-Dispatch Interval as the Initial MW value for that Pre-Dispatch Interval.

~~2.1.5.2.1.4.~~ AEMO's process for determining all Market Schedules and Scenarios will be as per the timeframes and provisions in chapter 7 of the WEM Rules and the WEM Procedure: Dispatch Algorithm Formulation.

3. Input Data for Market Schedules

3.1. Forecast Unscheduled Operational Demand and variations

AEPC_2024_15 Explanatory Note:

Paragraphs 3.1.1 and 3.9.3 have been amended to include reference to “Available Capacity Scenario”. Available Capacity Scenario is a newly defined term under the FCESS Cost Review Amending Rules and is applicable for the purposes of these respective paragraphs.

- 3.1.1. For all Market Schedules for the Reference Scenario and Available Capacity Scenario, AEMO will use the latest Forecast Unscheduled Operational Demand, as determined under the WEM Procedure: Forecast Unscheduled Operational Demand, to determine an input to the Dispatch Algorithm for the relevant Dispatch Interval or Pre-Dispatch Interval.

AEPC_2024_15 Explanatory Note:

Paragraphs 3.1.2, 3.1.3, 3.9.3 and 3.9.4 have been amended to replace “Market Schedules” with “Week-Ahead Schedules” and “Pre-Dispatch Schedules”. These paragraphs have also been amended to include reference to clause 7.8.6A(a) and 7.8.6A(b) (as applicable). These amendments are made to ensure alignment with amendments to clause 7.8.6 and 7.8.6A under the FCESS Cost Review Amending Rules, whereby the requirements to include Scenarios relevant to Pre-Dispatch Schedules are removed from clause 7.8.6 and added under the new clause 7.8.6A.

- 3.1.2. For all Week-Ahead Schedules and Pre-Dispatch Schedules ~~Market Schedules~~, for the purpose of the Scenarios under clause 7.8.6(b) and 7.8.6A(a), AEMO will use the methodology for determining a higher load forecast under the WEM Procedure: Forecast Unscheduled Operational Demand to determine an input to the Dispatch Algorithm.
- 3.1.3. For all Week-Ahead Schedules and Pre-Dispatch Schedules ~~Market Schedules~~, for the purpose of the Scenarios under clauses 7.8.6(c) and 7.8.6A(b), AEMO will use the methodology for determining a lower load forecast under the WEM Procedure: Forecast Unscheduled Operational Demand to determine an input to the Dispatch Algorithm.
- 3.1.4. For all Market Schedules and Scenarios, AEMO may use data that forecasts future system conditions, including regional load forecasts, in the Dispatch Algorithm in place of Network data determined under paragraph 3.3, for the purposes of determining forecast right hand side values for inputs to Constraint Equations.
- 3.1.5. Where AEMO uses forecast data under paragraph 3.1.4, it must make this data available to Market Participants under the same conditions that data produced under paragraph 3.2 are made available.

3.2. Essential System Service requirements

- 3.2.1. For all Market Schedules and Scenarios, AEMO will use the requirement for each Essential System Service as determined under the WEM Procedure: Essential System Service Quantities as inputs to the Dispatch Algorithm.

3.3. SCADA data and other network data

- 3.3.1. For the Primary Dispatch Interval or the first Pre-Dispatch Interval of a Pre-Dispatch Schedule or Week-Ahead Schedule, AEMO will use the following, for all Scenarios, as sources of real-time data from the SWIS and inputs to the Dispatch Algorithm where they are available, in descending order of preference:
- (a) SCADA data from AEMO's Energy Management System or from Western Power's SCADA system via Inter Control Centre Protocol;
 - (b) State Estimator data, where AEMO reasonably considers that this data is accurately modelled;
 - (c) data from AEMO's Historian, where AEMO reasonably considers that this data is no more than five minutes old;
 - (d) projected data based on outcomes, from the most recent Primary Dispatch Interval, of running the Dispatch Algorithm; or
 - (e) a default value that is expected to maintain Power System Security in typical operating conditions.
- 3.3.2. Where AEMO reasonably believes that data from a source listed in paragraph 3.3.1 is erroneous, AEMO may replace this data using another source listed in paragraph 3.3.1.
- 3.3.3. For any data source used under paragraph 3.3.1, AEMO will use the most recently available valid reading from the Dispatch Algorithm, at the time the Dispatch Algorithm solve is commenced for the relevant Primary Dispatch Interval.

3.4. ESS Trapezia values and Ramp Rates

- 3.4.1. For Market Schedules and Scenarios, AEMO will use Enablement Minimum, Low Breakpoint, High Breakpoint, Enablement Maximum, Maximum Upwards Ramp Rate, and Maximum Downwards Ramp Rate values for Registered Facilities, in accordance with the WEM Procedure: Adjustment of Real-Time Inputs, in the Dispatch Algorithm.

3.5. Unconstrained Injection Forecasts and Unconstrained Withdrawal Forecasts

- 3.5.1. In accordance with clause 7.8.7, AEMO will keep a record of the method that it uses to determine Unconstrained Injection Forecasts (UIF) and Unconstrained Withdrawal Forecasts (UWF) for Semi-Scheduled Facilities and Non-Scheduled Facilities in each Market Schedule and Scenario.
- 3.5.2. For all Market Schedules and Scenarios, AEMO may use other available data to determine UIF or UWF for a Facility, including, but not limited to:
- (a) AEMO's estimate of the current Injection or Withdrawal of the Facility;

- (b) the Market Participant's estimate of the UIF or UWF for the Facility provided by SCADA or an alternative communication medium that meets the requirements of the WEM Procedure: Communications and Control Systems;
 - (c) weather forecast data; and
 - (d) forecasts of Injection or Withdrawal provided by other external organisations engaged by AEMO.
- 3.5.3. AEMO may utilise a combination of data used under paragraph 3.5.2 and data provided by the Market Participant via its Real-Time Market Submission, to determine UIF or UWF for a Facility for a Dispatch Interval or a Pre-Dispatch Interval.

3.6. Other data provided via Real-Time Market Submissions

- 3.6.1. For all Market Schedules and Scenarios, AEMO will use data from a Registered Facility's effective Real-Time Market Submission as inputs to the Dispatch Algorithm, as applicable to the relevant Dispatch Interval or Pre-Dispatch Interval, where this is available to AEMO, unless otherwise specified in this Procedure.

3.7. Registration data

- 3.7.1. For all Market Schedules and Scenarios, AEMO will use effective Facility Standing Data and other registration data associated with a Registered Facility as inputs to the Dispatch Algorithm.

3.8. Constraint Sets and Constraint Equations

- 3.8.1. For all Market Schedules and Scenarios, AEMO will use Constraint Equations in accordance with the WEM Procedure: Dispatch Algorithm Formulation.
- 3.8.2. For all Market Schedules and Scenarios, AEMO will only use invoked Constraint Sets for a Network and their associated Network Constraints in the Dispatch Algorithm, as per the logic for invoking and revoking Constraint Sets and Constraint Equations in the WEM Procedure: Facility Dispatch Process.
- 3.8.3. For the Primary Dispatch Interval, for all Scenarios, AEMO will use the dispatch form of a Network Constraint for the Primary Dispatch Interval.
- 3.8.4. For all Scenarios, AEMO will use the pre-dispatch form of a Network Constraint for:
- (a) all Dispatch Intervals in the Dispatch Schedule, except the Primary Dispatch Interval; and
 - (b) all Pre-Dispatch Intervals in the Pre-Dispatch Schedule.
- 3.8.5. For all Scenarios, AEMO will use the Short Term PASA form of a Network Constraint for the Week-Ahead Schedule.

3.9. Dynamic Frequency Control Model and Facility Performance Factors

- 3.9.1. For all Market Schedules and Scenarios, AEMO will use the effective Dynamic Frequency Control Model (DFCM) as determined in the WEM Procedure: Essential System Service Quantities.
- 3.9.2. For the Primary Dispatch Interval, AEMO will use network data sourced under paragraph [3.33-2](#) to determine the Underlying System Load Operational Demand value that is used as part of the determination of the subset of the DFCM that will apply to the Dispatch Interval in question.
- 3.9.3. For all Market Schedules in relation to the Reference Scenario and the Available Capacity Scenario, AEMO will use the Fforecast Unscheduled Underlying Operational System Demand Load for the applicable Dispatch Interval or Pre-Dispatch Interval as part of the determination of the subset of the DFCM that will apply to:
- (a) all Dispatch Intervals in the Dispatch Schedule, except the Primary Dispatch Interval; and
 - (b) all Pre-Dispatch Intervals in the Pre-Dispatch Schedule and Week-Ahead Schedules.
- 3.9.4. For all Week-Ahead Schedules and Pre-Dispatch Market Schedules, for the Scenario produced under clause 7.8.6(b) or 7.8.6A(a), AEMO will use the load forecast determined under paragraph 3.1.2 for the applicable Dispatch Interval or Pre-Dispatch Interval as part of the determination of the subset of the DFCM that will apply to:
- (a) all Dispatch Intervals in the Dispatch Schedule, except the Primary Dispatch Interval; and
 - (b) all Pre-Dispatch Intervals in the Pre-Dispatch Schedule and Week-Ahead Schedules.
- 3.9.5. For all Week-Ahead Schedules and Pre-Dispatch Market Schedules, for the Scenario produced under clause 7.8.6(c) or 7.8.6A(b), AEMO will use the load forecast determined under paragraph 3.1.3 for the applicable Dispatch Interval or Pre-Dispatch Interval as part of the determination of the subset of the DFCM that will apply to:
- (a) all Dispatch Intervals in the Dispatch Schedule except the Primary Dispatch Interval; and
 - (b) all Pre-Dispatch Intervals in the Pre-Dispatch Schedule and Week-Ahead Schedules.
- 3.9.6. For all Market Schedules and Scenarios, AEMO will use its reasonable estimate of Inertia of the Load in the SWIS as an input to the Dispatch Algorithm for the Dispatch Interval or Pre-Dispatch Interval in question.
- 3.9.7. For all Market Schedules and Scenarios, AEMO will use the effective Facility Speed Factor for each Registered Facility, in conjunction with the effective DFCM, to determine Facility Performance Factors for Contingency Reserve Raise for Registered Facilities accredited to provide Contingency Reserve Raise.
- 3.9.8. For all Market Schedules and Scenarios, AEMO will use a Facility Performance Factor of 1.0 for Contingency Reserve Lower for all Registered Facilities accredited to provide Contingency Reserve Lower.

E[B] Note Facility Performance Factors

Clause 2.34A.6(e) states that the Facility Performance Factor for Regulation or RoCoF Control Service is 1.0 in all circumstances. Therefore, these values are not set in this Procedure.

3.10. Loss Factors

3.10.1. For all Market Schedules and Scenarios, AEMO will use the effective Transmission Loss Factors and Distribution Loss Factors for a Registered Facility as inputs to the Dispatch Algorithm for the purpose of calculating Loss Factor Adjusted Prices.

3.11. Constraint Violation Penalties

- 3.11.1. For all Market Schedules and Scenarios, AEMO will use the effective Constraint Violation Penalties as inputs to the Dispatch Algorithm.
- 3.11.2. AEMO may determine and use a different Constraint Violation Penalty, that is, not the default value specified in the WEM Procedure: Dispatch Algorithm Formulation, to apply to a Network Constraint, where it seeks to prioritise one Network Constraint relative to other Network Constraints, or to Constraints defined within the Dispatch Algorithm.

3.12. ESS Maximum Provision Percentages

3.12.1. For all Market Schedules and Scenarios, AEMO will use the effective ESS Maximum Provision Percentage for each of the Essential System Services, where this value can differ for each Essential System Service.

3.13. Market Service Price Ceilings and Floors

- 3.13.1. For all Market Schedules and Scenarios, AEMO will use the effective:
- (a) Energy Offer Price Ceiling;
 - (b) Energy Offer Price Floor; and
 - (c) FCESS Offer Price Ceilings.

3.14. Fast Start Facility data

- 3.14.1. For all Scenarios, for a Dispatch Interval in a Dispatch Schedule, except the Primary Dispatch Interval, for a Fast Start Facility, AEMO will use the Fast Start Target Mode from the solution to the Dispatch Algorithm in the previous Dispatch Interval as the Fast Start Current Mode for that Dispatch Interval.
- 3.14.2. For all Scenarios, for a Dispatch Interval in a Dispatch Schedule, except the Primary Dispatch Interval, for a Fast Start Facility, AEMO will use the Fast Start Target Mode Time from the solution to the Dispatch Algorithm in the previous Dispatch Interval as the Fast Start Current Mode Time for that Dispatch Interval.

3.15. Projected Facility Charge Levels

- 3.15.1. For all Scenarios, for a Dispatch Interval or Pre-Dispatch Interval, AEMO may generate a projection of expected charge availability for a Facility that contains an Energy Storage Resource, based on its Dispatch Target or Dispatch Forecast and any Essential System Service Enablement Quantities (or forecasts of these quantities), for the Dispatch Interval or Pre-Dispatch Interval.
- 3.15.2. Where AEMO produces a projection of expected charge availability under paragraph 3.15.1, AEMO will publish the methodology it uses to estimate this value on the WEM Website.

DRAFT

4. Application of Energy Storage Constraints in Market Schedules and Scenarios

- 4.1.1. Where a Market Participant requires AEMO to apply Energy Storage Constraints to a Registered Facility under clause 7.5.10, AEMO will apply the Pure Storage Constraints to that Registered Facility from the effective time indicated in a submission made by the Market Participant under Appendix 1(b)(xviA).
- 4.1.2. Where a Market Participant ~~is~~ no longer requires ~~ed~~ AEMO to apply Energy Storage Constraints to a Registered Facility under clause 7.5.10A, AEMO will cease to apply the Pure Storage Constraints to that Registered Facility from the effective time indicated in a submission made by the Market Participant under Appendix 1(b)(xviA).
- 4.1.3. For all Scenarios, where Energy Storage Constraints are applicable to a Registered Facility under paragraph 4.1.1, AEMO will apply the Pure Storage Constraints to the Registered Facility for Primary Dispatch Intervals.
- 4.1.4. For all Scenarios, AEMO will apply the Pure Storage Constraints to the Primary Dispatch Interval.
- 4.1.5. For all Scenarios, AEMO may apply the Pure Storage Constraints to:
- (a) all Dispatch Intervals, other than the Primary Dispatch Interval, in the Dispatch Schedule; and
 - (b) all Pre-Dispatch Intervals in the Pre-Dispatch Schedule and Week-Ahead Schedule.
- 4.1.6. Where AEMO applies the Pure Storage Constraints to Dispatch Intervals or Pre-Dispatch Intervals under paragraph 4.1.5, it will do so by estimating the state of charge and discharge of the Energy Storage Resource for the Registered Facility in those Dispatch Intervals or Pre-Dispatch Intervals, based on forecast dispatch outcomes.

Appendix A. Relevant clauses of the WEM Rules

Table 3 ~~Table-3~~ details:

- (a) the head of power clauses in the WEM Rules under which the Procedure has been developed; and
- (b) each clause in the WEM Rules requiring an obligation, process or requirement be documented in a WEM Procedure, where the obligation, process or requirement has been documented in this Procedure.

Table 3 Relevant clauses of the WEM Rules

Clause
7.8.9(a)
7.8.9(b)(i)
7.8.9(b)(ii)
7.8.9(c)(i)
7.8.9(c)(ii)

DRAFT