

AEMO Procedure Change Working Group (APCWG)

6 June 2024

This meeting is being recorded for note taking purposes



We acknowledge the Traditional Owners of country throughout Australia and recognise their continuing connection to land, waters and culture.

We pay respect to Elders past and present.

Agenda

1. Welcome
2. Discussion Item: *WEM Procedure: Mid Peak Electric Storage Resource Obligation Intervals*
3. Next Steps and Other Business

Please note that this meeting will be recorded by AEMO and may be accessed and used by AEMO for review and minuting purposes. By continuing, you consent to AEMO recording the call and using the recording for this purpose.

If you do not consent, you may exit the meeting.

Discussion Item

WEM Procedure: Mid Peak Electric Storage Resource
Obligation Intervals

Sandy Ng

Contents

- Background
- Summary of proposed changes to the Procedure
- Consultation timelines

Background

- Minister for Energy amended clause 4.11.3A of the WEM Rules as part of the RCM reforms on 17 April and 13 December 2023
- The latter amendment replaced Electricity Storage Resource Obligation Intervals (ESROI) with ‘Mid Peak’ ESROI (MPESROI)
- The existing ESROI procedure must be updated to:
 - Refocus the procedure to MPESROI
 - Reflect recent relevant changes to the LT PASA arrangements
 - Set out the circumstances that allow AEMO to determine changes to previously published MPESROI to support clauses 4.11.3A and 6.3.1 of the WEM Rules
 - Comply with changes to clause 4.11.3A(c)(iii) of the WEM Rules with respect to consultation

Summary of proposed changes

- Rename the procedure, and replace ESROI with MPESROI throughout
- Definition of ‘Peak Demand Period’ amended to reflect the new basis new for identifying the Trading Intervals that comprise the Peak Demand Period:
 - peak demand forecasts developed as part of the Long Term PASA
 - number of contiguous Trading Intervals is equal to the ESR Duration Requirement (no longer limited to 8)
- Refocus the procedure to the determination of whether changes are required to previously determined and published MPESROI
- Describe the circumstances for changing and requirements for publishing:
 - MPESROI determined in accordance as per clause 4.11.3A of the WEM Rules
 - MPESROI determined and recorded in accordance with clause 6.3.1 of the WEM Rules
- Remove consultation process to align with changes to clause 4.11.3A(c)(iii) of the WEM Rules
- Describe the publication requirements for MPESROI that have changed

Consultation

- The publication date for WEM Procedure: Mid Peak Electric Storage Resource Obligation Intervals is 22 May 2024.
- The indicative submission close date is 30 June 2024.
- Consultation information is available at - <https://aemo.com.au/energy-systems/electricity/wholesale-electricity-market-wem/procedures-policies-and-guides/procedures/ongoing-procedure-change-proposals>
- If you have further questions on the consultation, please contact WA.MarketDevelopment@aemo.com.au.

Process Stage	Indicative Date
Publication of consultation	22 May 2024
Closing date for submissions on Procedure Change Proposal	20 June 2024
Publication of Final Procedure	28 June 2024
Proposed commencement of amended WEM Procedure	1 July 2024

Questions?

- Any feedback or further questions can be sent to WA.MarketDevelopment@aemo.com.au



For more information visit

aemo.com.au